

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/361

Dated: 04/11/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of M/s **KFC Restaurant** located at **Ground floor only**, Shop No C-5, Ground floor, Main Market, Malviya Nagar, New Delhi-110017 in the building comprised of Basement, Ground plus Three upper Floor owner/occupied by A Unit of Sapphire Foods India Pvt. Ltd was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2021/SZ/269 dated 01/10/2021. The restaurant premise was re-inspected by the officer concerned of this department on 25/10/2024 in the presence of Ms. Arti (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Restaurant running at GF only) and **Validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/11/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, PS Defence Colony, New Delhi 110049 (Ref. MHA Portal ID 202410071515341 dated 07/10/2024)

Conditions for the validity of Fire Safety Certificate: -

1. **This FSC is valid for Ground floor only.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

2/13

INSPECTION REPORT				
1	Name & Address of the Building	KFC Restaurant, (Sapphire Food India Ltd) Shop No C-5, Ground floor, Main Market, Malviya Nagar, New Delhi-110017		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, ground, plus 03 upper floors (restaurant running at ground floor only)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2021/SZ/269 dated 01/10/2021		
6	Fire Safety Directives Letter No	NBC Part IV		
7	Date of Inspection	25/10/2024		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Arti (Manager)		
10	Year of construction	1980 as mentioned in MHA ID		
11	Applicant letter No.	MHA Portal ID 202410071515341 dated 07/10/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Restaurant	6 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.5 m each	1.80 mtr & 1.50 mtr	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	04 Nos	06 Nos.	MR
	• Types		ABC-04, W.CO ₂ -02	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Required	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic Fire Detection and Alarming system.			

~

12/1/14

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground floor 	NA	Provided in Restt.	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	Required	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	NA	N/A
	<ul style="list-style-type: none"> 2. Hose box. 	N/A	NA	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	N/A	NA	N/A
	<ul style="list-style-type: none"> ➤ Access to pump house 	N/A	NA	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector System Panel. 	N/A	NA	N/A

2

m/15

<ul style="list-style-type: none"> • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 351 dated 27/08/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2021/SZ/269 dated 01/10/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Handwritten signature
28/10/24

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (South)

Handwritten signature
28/10/24

Handwritten signature
CFO (HOS)

Handwritten signature
28/10/2024

Handwritten signature
29/10/24

Handwritten signature
Any ADO

As approved, F-1 letter is put up for your signature A

Handwritten signature
30/10

Handwritten signature
Director

Updated
05/11/24