



FIRE SAFETY CERTIFICATE

Certified that the M/s Wood Apple Restaurant at Plot No. 03, Hargovind Enclave, Delhi - 110092, owned / occupied by A Unit of Woodapple Residency, comprised of basement, stilt plus upper ground plus three upper floors was granted fire safety certificated vide letter no. F6/DFS/MS/EH/2021/NDZ/304 dated 25/10/2021. The restaurant building was re-inspected by the officer concerned of this department on 22/10/2023 in the presence of Mr. Sanjeev (Manager) and found that the restaurant building have deemed complied the fire prevention and fire safety requirements in accordance with the Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D "Assembly building" Restaurant running at upper ground floor only valid up to 31/03/2027 on period of in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued 04/11/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
ok (w)

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, 419 Udyog Sadan, Patparganj Industrial Area, Delhi - 110092, kindly insure the occupancy as detailed above and deviation, if any.
2. The Joint Commissioner of Police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.r.t. - MHA portal ID - 2024101015515 dated 10/10/2024.
3. The Manager, M/s Wood Apple Restaurant (A Unit of Woodapple Residency) at Plot No. 03, Hargovind Enclave, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for upper ground floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. Presently basement is being used for storage purpose.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Wood Apple Restaurant (A Unit of Woodapple Residency at Plot No. 03, Hargovind Enclave, Delhi - 110092)
2	Building is comprised of	Basement, Stilt + Upper Ground + 03 Upper floors (Restaurant running on upper ground floor only)
3	Type of occupancy	Assembly Building
4	Type of case	Renewal Case
5	Details of previous FSC	F6/DFS/MS/EH/2021/NDZ/304 dated 25/10/2021
6	Fire safety direction letter no.	DFS Act, 2007 and Rules 2010
7	Date of inspection	22/10/2024
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)
9	Name of the designation of officer From the building side	Mr. Sanjeev (Manager)
10	Year of construction	2010
11	Applicant's letter no	Application No. LD 2024101015515 dated 10/10/2024

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
a	Road width	06 meters	30 meters ✓	MR
b	Gate width	N/A	N/A	N/A
c	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
A	Number of staircases			
a	Upper floor	02 nos.	03 nos. ✓	MR
b	Basement	01 nos.	02 nos.	MR
B	Width of staircases			
a	Upper floor	1.5 mtrs & 1.25 mtrs.	1.15 mtr, 0.75 mtr (stilt to ground) & 1.15 mtr (Basement to terrace)	MR (Accepted Earlier)
b	Basement	1.25 mtrs.	1.15 mtrs & 2.0 mtrs.	MR (Accepted Earlier)
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	01 no.	MR
E	Width of corridor	N/A	N/A	N/A
F	Door size	2.0 meters & 1.0 meter.	2.0 meters & 1.0 meter. ✓	MR (Accepted Earlier)
3	Compartmentation			
a	Fire check door	N/A	N/A	N/A
b	Sealing of electrical shafts	N/A	N/A	N/A
c	Fire rating of shaft door	N/A	N/A	N/A
d	Water curtain	N/A	N/A	N/A
e	Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
a	Basement	N/A	N/A	N/A
b	Upper floor	N/A	N/A	N/A

NLM

5.	Fire Extinguisher				
	a	Total numbers	10 nos.	10 nos.	MR
	b	Types	ABC/CO ₂	ABC/CO ₂	MR
	c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.				
	a	Total numbers of each floor	01 no.	01 no.	MR
	b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	c	Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.				
	a	Type of detectors	NA	NA	NA
	b	Location of main panel	NA	NA	NA
	c	Location of repeater panel	NA	NA	NA
	d	Alternate source of power	NA	NA	NA
	e	Hooter's location	NA	NA	NA
8	MOEFA		NA	Provided	NA
9	Public address System.		NA	NA	NA
10	Automatic Sprinkler System.				
	a	Basement	Required	Provided	MR
	b	Upper floors	NA	NA	NA
	c	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants				
	a	Size of riser	100 mm	Provided	MR
	b	Number of hydrants per floor	01 no.	Provided	MR
	c	Hose Box	01 no.	Provided	MR
12	Yard Hydrants.				
	a	Total number of hydrants	NA	NA	NA
	b	Hose Box	NA	NA	NA
13	Pumping Arrangements.				
	A	Ground Level			
	a	Discharge of main Pump	NA	NA	NA
	b	Head of Main Pump	NA	NA	NA
	c	Number of main pumps	NA	NA	NA
	d	Jockey pump out put	NA	NA	NA
	e	Jockey pump head	NA	NA	NA
	f	Standby pump out put	NA	NA	NA
	g	Standby pump head	NA	NA	NA
	h	Auto starting /manual stopping	NA	NA	NA
	i	Pump House Access	NA	NA	NA
	B	Terrace Level			
	a	Discharge of pump	450 LPM.	450 LPM.	MR
	b	Head of the Pump	40 mtrs.	40 mtrs.	MR
	c	Power supply	Required	Provided	MR
	d	Auto Starting of pump	Required	Provided	MR


W


Woodappe Residency at Plot No. 03, Hargovind Enclave, Delhi 110092


14	Captive Water Storage for Fire Fighting.				
	a	Underground tank capacity	NA	NA	NA
	b	Draw-off connection	NA	NA	NA
	c	Fire service inlet	NA	NA	NA
	d	Access to tank	NA	NA	NA
	e	Overhead Tank capacity	5,000 liters.	5,000 liters	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	a	Pressurization of Lift Shaft	NA	NA	NA
	b	Pressurization of Lift lobby	NA	NA	NA
	c	Communication in lift car	NA	NA	NA
	d	Firemen's grounding switch	NA	NA	NA
	e	Lift Signage	NA	NA	NA
17	Standby power supply		NA	Provided	NA
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	NA	NA	NA
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:				
			NA	NA	NA


e Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC issued vide letter no. F6/DFS/MS/EH/2021/NDZ/304 dated 25/10/2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



 25/10/2024
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO/Laxmi Nagar

~~DY.CFO/NDZ~~

 28/10/24


~~C.F.O.~~

 27/10/2024

~~Director~~

 30/10/24

Sir. F.T letter is autup for sign. Pleasly

~~Director~~

 1/11/24

Uploaded
 04/11/24


 01/11/2024