

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024/EH/369

Dated: 08/11/2024

FIRE SAFETY CERTIFICATE

Certified that M/s Haldiram Products Pvt. Ltd. Located at Shop No 11A, Ground Floor, Pusa Road, Karol Bagh, New Delhi, in a building comprised of Basement + Ground + 03 Upper Floors was issued FSC vide letter No. F6/DFS/MS/EH/2021/SZ/312, dated 28/10/2021. The premises was inspected by the officer concerned of this department on 28/10/2024 in the presence of Sh. Sudhir Sharma (Licensing Officer) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly" Group D (**Ground Floor**) with effect from 08/11/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on08/11/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, New Delhi.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
3. The Manager, M/s Haldiram Products Pvt. Ltd. Located at Shop No 11A, Ground Floor, Pusa Road, Karol Bagh, New Delhi.

Condition for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s Haldiram Products Pvt. Ltd. Located at Shop No 11A, Ground Floor, Pusa Road, Karol Bagh, New Delhi.
2. Type of Occupancy : Class-D (Assembly)(At Ground Floor in a building comprised of Basement, Ground + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2021/SZ/312, dated 28/10/2021
5. Fire Safety directives L. No. : Nil
6. Date of inspection : 28/10/2024
7. Name of the Inspecting Officer ; ADO (DWK)
8. Name and designation of Officer
from the building side Sh. Sudhir Sharma (Licensing Officer)
9. Year of Construction. : 2021
10. Applicant's letter No. : 2024100415207, dated 04/10/2024

Basement=Office(Now vacant)
G.F= Haldiram
F.F= Institute
S.F=Shops
T.F - Restaurant


S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/1, N/2 & N/3	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	Required	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	Restaurant running at GF only
	• Basements	NA	NA	Restaurant running at GF only
	b. Width of staircases			
	• Upper floors	NA	NA	Restaurant running at GF only
	• Basements	NA	NA	Restaurant running at GF only
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Mechanical ventilation	MR


5.	Fire Extinguishers			
	• Total numbers	6 nos.	Provided	MR
	• Types	ABC, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required with in restaurant area	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	Provided	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	150 mm	MR
	• Number of hydrants per floor	01 No.	Provided	MR
	• Hose Box	01 No.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• Auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	• Terrace level			
	• Discharge of pump	450 lpm	Provided	MR
	• Head of the pump	40 m	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	• Draw off connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA

Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
Standby power supply	Required	Provided	MR
Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	Required	02 ABC type fire extinguisher found provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No F6/DFS/MS/EH/2021/SZ/312, dated 28/10/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer
Name: Uday Vir Singh
Designation: ADO/DWK


CFO/S2
4/11/21

As directed please
desmed.


Director
8/11/21
m


6/11/2021