

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 673

Dated: 14/11/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s CNG Filling Station (IGL) Located at Sector – 23 B, Phase-II, Dwarka, New Delhi – 110075 comprised of Ground + 01 Upper Floor was issued NOC vide Letter No. F6/DFS/MS/SZ/2021/CNG/439, dated- 10/09/2021. The premises was re inspected by the officer concerned of this department on 28/10/2024 in the presence of Mr. Manoharlal (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “Hazardous” (CNG filling station) with effect from 14/11/24 for a period of three years.

Issued on 14/11/24.... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service.
OK
14/11/24

Copy to:

1. Sh.Ajay Khatri GM – Fire & Safety IGL Bhawan, Plot No 4, Community Centre, Sector-09, R.K Puram, New Delhi - 110022.
2. The Manager, M/s CNG Filling Station (IGL) Located at Sector – 23 B, Phase-II, Dwarka, New Delhi – 110075.

Condition for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement if any shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/24

INSPECTION REPORT

1. Name & address of the building: M/s CNG Station (IGL) Located at Sector - 23 B, Phase-II, Dwarka, New Delhi
2. Type of Occupancy : Group J: Hazardous (CNG Filling Station)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SZ/2021/CNG/439, dated- 10/09/21.
5. Fire Safety directives L. No. : OISD -179/F5/(3A)/DFS/CNG/BP/2012/1487 dated 25/04/2012
6. Date of inspection : 28/10/2024
7. Name of the Inspecting Officer : Sh. Uday vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Manoharlal (Manager)
9. Year of Construction : 2012
10. Applicant's letter No. : IGL/F&S/2024/15/85/2 dated 09/10/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/18, N/19 & N/20	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	30 m	MR
	• Gate width	4.5m	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	120cm & 70 cms	120cm & 70 cms	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR


Sh. Uday Vir Singh


N/26


16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No F6/DFS/MS/SZ/2021/CNG/439, dated- 10/09/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name: Sh. Udaivir Singh
 Designation : ADO (DWK)

 5/11/24

 5/11/2024

 ADO/DWK

bit AP letter to put up for sig ple

 5/11/24

 5/11/24