



No.F6/DFS/MS/School/SZ/2024/1114

Dated: 18/11/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Hemnani Public School located at Baba Nebhraj School Marg, Opp. G – Block, Lajpat Nagar-I, New Delhi-24, comprised of Ground + 02 upper floors, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/SZ/386 dated 31.05.2021. The school building was re-inspected by officer concerned of this department on 13.11.2024 in the presence of Mrs. Geeta Balani (Principal) and found that school building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the school premises/building is fit for occupancy of Group B “Educational Building” (School) with effect from18/11/2024... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....18/11/2024...at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

13/11/24

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, M/s Hemnani Public School located at Baba Nebhraj School Marg, Opp. G – Block, Lajpat Nagar-I, New Delhi-24.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J’ [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

| | | | | | | |
|------|--|--|-----------------------------|-----------------------|-------------|----|
| 1 | Name & address of the building | M/s Hemnani Public School located at Baba Nebhraj School Marg, Opp. G - Block, Lajpat Nagar-I, New Delhi-24. | | | | |
| 2 | Building is comprised of | Ground + 02 upper floors | | | | |
| 3 | Type of occupancy | Group B- Education Building | | | | |
| 4 | Type of case | Renewal | | | | |
| 5 | Details of previous FSC | F6/DFS/MS/School/2021/SZ/386 dated 31.05.2021 | | | | |
| 6 | Fire safety direction letter no. | DOE Circular 262-362 dated-17/01/2005 | | | | |
| 7 | Date of inspection | 13.11.2024 | | | | |
| 8 | Name of the inspecting officers | Rajesh Kumar Shukla, ADO (M. Road) | | | | |
| 9 | Name of the designation of officer from the building side | Mrs. Geeta Balani (Principal) | | | | |
| 10 | Year of construction | 2005 | | | | |
| 11 | Applicant's letter no. | Outdoor diary no. 8437 dated 29.10.2024 | | | | |
| S.No | Minimum standard of fire prevention and fire safety U/R 33 | Requirement as per DOE Circular dated 17.01.2005 | Provided at site | Remarks MR/NMR | | |
| 1 | Access to Building: | | | | | |
| | A | Road width | Required | 6.0 m | MR | |
| | B | Gate width | NA | NA | NA | |
| | C | Width of internal road | NA | NA | NA | |
| 2 | Number, Width, Type and Arrangement of Exits: | | | | | |
| | A | Number of staircases | | | | |
| | | a | Upper floor | Required | 02 nos. | MR |
| | | b | Basement | NA | NA | NA |
| | B | Width of staircases | | | | |
| | | a | Upper floor | 2 nos. (Exits) | 1.42 m each | MR |
| | | b | Basement | NA | NA | NA |
| | C | Protection of exits | | | | |
| | | a | Fire check door | NA | NA | NA |
| | | b | Pressurization | NA | NA | NA |
| | D | No. of continuous staircases to terrace | Required | | 01 no. | MR |
| | E | Width of corridor | NA | | NA | NA |
| | F | Door size | 1.0 mtrs. (for class rooms) | | Provided | MR |
| 3 | Compartmentation: | | | | | |
| | A | Fire check door | NA | NA | NA | |
| | B | Sealing of electrical shafts | NA | NA | NA | |
| | C | Fire rating of shaft door | NA | NA | NA | |
| | D | Water curtain | NA | NA | NA | |
| | E | Fire dampers | NA | NA | NA | |
| 4 | Smoke Management System: | | | | | |
| | A | Basement | NA | NA | NA | |
| | B | Upper floor | NA | NA | NA | |
| 5. | Fire Extinguisher: | | | | | |
| | A | Total numbers | 09 nos. | 12 nos. | MR | |
| | B | Types | CO ₂ & ABC | CO ₂ & ABC | MR | |
| | C | ISI marking | ISI Marked | Provided | MR | |
| 6 | First-Aid-Hose Reel: | | | | | |
| | A | Total numbers of each floor | 01 no. | 01 no. | MR | |
| | B | Length of hose reel hose | 30 mtrs. | 30 mtrs. | MR | |
| | C | Nozzle diameter | 05 mm | 05 mm | MR | |
| 7 | Automatic Fire Detection and Alarming System: | | | | | |
| | A | Type of detectors | NA | NA | NA | |
| | B | Location of main panel | NA | NA | NA | |
| | C | Location of repeater panel | NA | NA | NA | |
| | D | Alternate source of power | NA | NA | NA | |
| | E | Hooters | NA | NA | NA | |

| | | | | |
|----|---|--------------------------------|------------|----------|
| 8 | MOEFA: | NA | NA | NA |
| 9 | Public Address System: | NA | Provided | NA |
| 10 | Automatic Sprinkler System: | | | |
| | A | Basement | NA | NA |
| | B | Upper floor | NA | NA |
| | C | Sprinkler above false ceiling | NA | NA |
| 11 | Internal Hydrants: | | | |
| | A | Size of riser/down-comer | 100 mm | 100 mm |
| | B | Number of hydrants per floor | 01 no. | 01 no. |
| | C | Hose box | 01 no. | 01 no. |
| 12 | Yard Hydrants: | | | |
| | A | Total number of hydrants | NA | NA |
| | B | Hose box | NA | NA |
| 13 | Pumping Arrangements: | | | |
| A | Ground level | | | |
| | a) | Discharge of main pump | NA | NA |
| | b) | Head of main pump | NA | NA |
| | c) | Number of main pumps | NA | NA |
| | d) | Jockey pump out put | NA | NA |
| | e) | Jockey pump head | NA | NA |
| | f) | Standby pump out put | NA | NA |
| | g) | Standby pump head | NA | NA |
| | h) | Auto starting /manual stopping | NA | NA |
| | i) | Pump house access | NA | NA |
| B | Terrace Level | | | |
| | a) | Discharge of pump | Required | 450 LPM |
| | b) | Head of the pump | 40 mrts | Provided |
| | c) | Power supply | Required | Provided |
| | d) | Auto starting of pump | Auto | Provided |
| 14 | Captive Water Storage for Fire Fighting: | | | |
| | A | Underground tank capacity | NA | NA |
| | B | Draw-off connection | NA | NA |
| | C | Fire service inlet | NA | NA |
| | D | Access to tank | NA | NA |
| | E | Overhead tank capacity | 5,000 ltrs | Provided |
| 15 | Exit Signage: | Required | Provided | MR |
| 16 | Provision of Lifts: | | | |
| | A | Pressurization of lift shaft | NA | NA |
| | B | Pressurization of lift lobby | NA | NA |
| | C | Communication in lift car | NA | NA |
| | D | Firemen's grounding switch | NA | NA |
| | E | Lift signage | NA | NA |
| 17 | Standby Power Supply: | NA | NA | NA |
| 18 | Refuge Area: | | | |
| | A | Total area | NA | NA |
| | B | Location | NA | NA |


| | | | | | |
|-----------|---|-----------------------|----|----|----|
| 19 | Fire Control Room: | | | | |
| | A | Detector system panel | NA | NA | NA |
| | B | Flow switch panel | NA | NA | NA |
| | C | PA system panel | NA | NA | NA |
| | D | Battery backup | NA | NA | NA |
| | E | Building floor plans | NA | NA | NA |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | | | NA | NA |

LEGENDS:-Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).


The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

The shortcomings issued to the building by this department vide letter no. F6/DFS/MS/School/SZ/2024/464 dated 25.07.2024 has been rectified by the school management.


In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/School/2021/SZ/386 dated 31.05.2021 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.


13.11.24
Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD) 

COO (PDS) 
18/11/2024

Director 
18/11/24


18/11/24

