

C-205

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 681

Dated:-20/11/2024

FIRE SAFETY CERTIFICATE

Certified that Russian Federation located at 25, Barakhamba Road, New Delhi comprised of 3 Basement + Lower Ground + Upper Ground + 10 Upper floors owned /occupied by Russian Federation was earlier granted FSC vide letter No F6/DFS/MS/NDZ/2021/481 dated 04/10/21. Now, the premises was re-inspected by the officers concerned of this department on dated 13/11/24 in presence of Sh. Amardeep Singh and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class -**Business Building** with effect from 20/11/2024..... 2024 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...20/11/2024..... at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika kendra, New Delhi.
2. The Estate Manager, Russian Federation at 25, Barakhamba Road, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction, electrical installation, set back area etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as staircase , passage way , exits , etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building:- Russian Federation, 25, Barakhamba Road, New Delhi
2. Type of occupancy:- Business Building (3 Basement, L.Ground + upper ground +10 upper Floors)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/NDZ/2021/481 dated 04/10/21.
5. Fire safety directives No.- F6/DFS/MS/2001/1617 dated 08/08/2001.
6. Date of inspection:- 13/11/24.
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal (DO (CD)
8. Name & designation of officer
From the building side:- Sh. Amardeep, Estate Manager
9. Year of construction:- Old
10. Applicant's letter No:- Letter no. nil dated 21/10/24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	35 mtr. ✓	MR
	2) Gate width	4.5 mtr.	7.50 mtr.	MR
	3) Width of internal road	06 mtr.	Provided	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03 Nos.	03 Nos.	MR
	2. Basements	06 Nos.	06 Nos. ✓	MR
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.25 x 2 & .90 mtr.. ✓	MR
	2. Basements	1.25 mtr.	1.25 x 2 & .90 mtr. x 4 ✓	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	02 no.	02no.	MR
	E. Width of corridor	1.5 mtr.	Provided	MR
	F. Door size	1.25 mtr.	1.25 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	120 Nos.	130 Nos. ✓	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Yes	MR

6.	First-Aid Hose Reel			MR
	1) Total number of each floor	2 no.	2 no.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	
7.	Automatic Fire Detection & Alarming System			MR
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Ground floor	Ground floor	MR
	3) Location of repeater panel	Security Room	Provided	
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Every floor	Every floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm.	MR
	2) Number of hydrants per floor	2 Nos.	2 Nos.	MR
	3) Hose box at each floor	2 Nos.	2 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	04 Nos.	04 Nos.	MR
	2) Hose box	04 Nos.	04 Nos.	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	150 mtr.	150 mtr.	MR
	c) Number of main pump	2 Nos.	2 Nos.	MR
	d) Jockey pump out put	280 LPM	280 LPM	MR
	e) Jockey pump head	150 mtr.	150 mtr.	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	150 mtr.	150 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	3,00,000 ltrs.	3,00,000 ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	25,000 ltrs.	25,000 ltrs. provided	MR

		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	Provided ✓	MR
	b) Pressurization of lift lobby (basement)	Required	Provided ✓	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	Provided	N/A
	Total area location	N/A	Provided	N/A
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: Co2, ABC Type Extinguisher			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter no. F6/DFS/MS/NDZ/2021/481 dated 04/10/21, renewal under rule 35(6) of the Delhi Fire Service rules 2010, Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Handwritten Signature]
18/11/24

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

[Handwritten Signature]
18/11/24

Name :- Sh. Ravinder Singh
Designation : ADO (CC)

[Handwritten Signature]
19/11/24

[Handwritten Signature]
19/11/24

C.F.O /

[Handwritten Signature]
19/11/24
Director

[Handwritten Signature]

As approved DT is put up for kind perusal and
signature please
Director
[Handwritten Signature]
19/11/24

[Handwritten Signature]
20/11/24