

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/451

Dated: 14/11/2024

FIRE SAFETY CERTIFICATE

Certified that the "Sindh Palace" Guest House located at 7966, Arakashan Road, Ram Nagar, Pahar Ganj, New Delhi comprised of Ground + 04 Upper floors, Ground floor (Reception + 01 guest rooms), 1st floor to 3rd floor (02 guest rooms at each floor) 4th and above floor not in use as per affidavit dated 26.09.2021, total 07 guest rooms up to third floor only, owned/occupied by Sindh Palace Guest House was earlier granted FSC by this department vide letter No. F6/DFS/MS/GH/NDZ/2021/325 dated 23/08/2021. Now, the premise was re-inspected by the officer concerned of this department on 06/11/24 in the presence of Mr. Bahseen and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 Ground floor (Reception + 01 guest rooms), 1st floor to 3rd floor (02 guest rooms at each floor), total - 07 guest rooms up to third floor only and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ...14/11/2024....at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre , New Delhi. : to ensure that not to use any floor above third floor for any purpose
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.ID No. 2024102115916 dated 21-10-2024.
3. The Manager, "Sindh Palace" Guest House 7966, Arakashan Road, Ram Nagar, Pahar Ganj, New Delhi.

Condition for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. **This FSC is valid for guest house up to third floor only.**
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as staircase , exits , corridor , etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

11/29
INSPECTION REPORT

1. Name & address of the building "Sindh Palace" Guest House at 7966, Arakashan Road, Ram Nagar, Pahar Ganj, New Delhi.
2. Type of occupancy:- Residential, Sub Division-A-1
Gr. + 03 Upper floors (total 07 Guest rooms)
Ground floor (Reception + 01 guest rooms)
1st floor to 3rd floor (02 guest rooms at each floor)
having an affidavit dated 26.09.2021 submitted by owner regarding not to use any floor above third floor.
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/GH/NDZ/2021/325 dated 23/08/2021.
5. Fire safety directives No.- N/A
6. Date of inspection:- 06/11/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Sh. Bhaseen (Manager)
9. Year of construction:-
10. Applicant's letter No: ID No. 2024102115916 dated 21-10-2024.

Old Case(renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	N/A	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	1.15 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

N/30

6.	First-Aid Hose Reel				
	1) Total number of each floor	N/A	01	<	N/A
	2) Length of hose reel hose	N/A	30mtr		N/A
	3) Nozzle diameter	N/A	5 mm		N/A
7.	Automatic Fire Detection & Alarming System				
	1) Type of detectors Co type	Required	Provided		MR
	2) Location of main panel	Ground floor	Provided		MR
	3) Location of repeater panel	N/A	N/A		N/A
	4) Alternate source of power	Required	Provided		MR
	5) Hooter's Location	Ground floor	Provided		MR
8.	MOEFA	Required	Provided		MR
9.	Public Address System (Inter come)	Required	Provided		MR
10.	Automatic Sprinkler System				
	1) Basement	N/A	N/A		N/A
	2) Upper floors	N/A	N/A		N/A
	3) Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				
	1) Size of riser/down-comer	N/A	N/A		N/A
	2) Number of hydrants per floor	N/A	N/A		N/A
	3) Hose box	N/A	N/A		N/A
12.	Yard Hydrants				
	1) Total number of hydrants	N/A	N/A		N/A
	2) Hose box	N/A	N/A		N/A
13.	Pumping Arrangement				
	1) Ground level	N/A	N/A		N/A
	a) Discharge of main pump	N/A	N/A		N/A
	b) Head of main pump	N/A	N/A		N/A
	c) Number of main pump	N/A	N/A		N/A
	d) Jockey pump out put	N/A	N/A		N/A
	e) Jockey pump head	N/A	N/A		N/A
	f) Stand by pump output	N/A	N/A		N/A
	g) Stand by pump head	N/A	N/A		N/A
	h) Auto starting/Manual stopping	N/A	N/A		N/A
	2) Terrace level				
	a) Discharge of pump	N/A	N/A		N/A
	b) Head of pump	N/A	N/A		N/A
	c) Power supply	N/A	N/A		N/A
	d) Auto starting of pump	N/A	N/A		N/A
14.	Captive Water Storage for Fire Fighting				
	1) Under ground tank capacity	N/A	N/A		N/A
	a) Draw-off connection	N/A	N/A		N/A
	b) Fire service inlet	N/A	N/A		N/A
	c) Access to tank	N/A	N/A		N/A
	d) Over head tank capacity	N/A	N/A		N/A

N/B1

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The above fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. F6/DFS/MS/GH/NDZ/2021/325 dated 23/08/2021. Under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, DFA is prepared and put up for kind perusal/approval please.

Signature of the Inspecting Officer

[Handwritten Signature]

Name: - Ravinder Singh

Designation: - ADO (CC)

[Handwritten Signature]

[Handwritten Signature]

11/11/24

Dy. C.O. (AD2)

[Handwritten Signature]

11/11/24

C.F.O.

[Handwritten Signature]

11/11/2024

Director

[Handwritten Signature]

[Handwritten Signature]