



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7.
आजमती =
अमृत मंदिर

No. F6/DFS/MS/School/WZ/2024/ 1120

c/61
Dated:- 22/11/2024

FIRE SAFETY CERTIFICATE

Certified that the C. R. Saini Public School Located at E-Block, Saini Vihar, Laxmi Park, Nangloi, Delhi-110041, comprised of Basement + Ground + 03 Upper Floors (U-Shape) & earlier the School building was comprised of Ground + 03 Upper Floor & Basement + Ground + 03 Upper Floors (L-type) and was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2020/467 dated 04/11/2020, owned/occupied by C. R. Saini Public School, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and Verified by the officer concerned of Fire Service on 29/10/2024 in the presence of Sh. Sanjeev Saini (Owner) and that the premises/building is fit for occupancy class "Educational Building" Group B (for Basement, Ground plus Three Upper Floors Except another block ground plus three upper floors) with effect from 22/11/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 22/11/2024 at New Delhi by.

(Atul Garg)

Director

Tel. No. 011-23414000

Copy to :-

1. The Deputy Director, Municipal Corporation of Delhi, Civic Centre, Minto Road, Delhi-110002.
2. The Principal, C.R. Saini Public School, E-Block, Saini Vihar, Laxmi Park, Nangloi, Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The school manager has given an undertaking that they shall use the basement only as per the Building Bye Laws laid down for the basements.

INSPECTION REPORT

1. Name & address of the building : **C.R. Saini Sr. Sec. Public School**, located at **E-Block, Laxmi Park, Saini Vihar, Nangloi, Delhi-110041**
2. Type of Occupancy : Educational,
3. Type of Case : New Case/Alteration/Addition
4. Details of previous NOC : F6/DFS/MS/School/WZ/2020/467 dated 04/11/2020
5. Fire Safety directives Letter No. : NBC (Part-IV)/Cr. No. 3298-3398 dated 01/03/2011
6. Date of inspection : 29/10/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Sanjeev Saini (Owner)
9. Year of Construction : 2015
10. Applicant's letter No. : CRS/Adm./2024/874 dated 01/10/2024

The building is comprised of Basement + Ground + 03 Upper Floors (U-shape).

S No	Minimum standards on fire prevention and fire safety U/R 33	Directive letter dated 04.03.2016 Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	03	MR
	• Basements	01	01	MR being old case
	b. Width of staircases			
	• Upper floors	1.5 m each	1) 1.80 m x 1 (from basement to terrace) 2) 1.52 m x 1 (from ground to 3 rd floor) width of this 2 nd staircase is varying from 1.52 to 1.30 m i.e. there are 7 flights in this staircase having width 1.52 m in 4 flights 1.30 m in flights) 3) 1.50 m x 1 (from ground to terrace)	MR
	• Basements	N/A	1.8 m x 1	N/A
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR

	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			MR
	• Total numbers	14 nos.	20 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR
6.	First - Aid Hose Reels			MR
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System			MR
10.	Automatic Sprinkler System	Required	Provided	NA
	• Basements	NA	NA	NA
	• Upper Floor/Open.	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:	NA	NA	NA
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			NA
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• Auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	• Terrace level	450 lpm x 2	Provided	MR
	• Discharge of pump	40 m	Provided	MR
	• Head of the pump	Required	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			NA
	• Under ground tank capacity	NA	NA	NA
	• Draw off connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000Ltrs.	Provided.	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

NOTE : 1) The owner/occupier of the school building have submitted an affidavit that the school is located in non-confirming area and Abaadi kshetra & the drawing are not approved by MCD. The owner/occupier have submitted as built plan duly signed by registered Architect and owner of the school, which may be accepted.

2) The school manager has given an undertaking that we shall use the basement only as per the laws laid for the basements.

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety requirements under the rules, grant of Fire Safety Certificate is recommended under rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is prepared & put up for approval please.

CFJ/W2

Aman Kumar
Aman Kumar Pathar
ADO (JWP)

ID *14/11/2024*

CFJ
Vugh
14/11/2024
Director
14/11/2024

Sir, FF letter is put-up for your signature lot.

Director
14/11/2024

Aman Kumar
14/11/2024
Aman (JWP)