

2/108

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F.6/DFS/MS/2024/EH/WZ/ 381

Dated 22/11/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Jubilant Food Works Limited Dominos Pizza Shop No.G-91, Gr. floor, Plot No.17, District Centre, Manglam Place, Sector-3, Rohini, Delhi-110085. Previously name of Pizza Hut restaurant in the building comprised of basement + ground + 03 upper floors was granted NOC by this department vide letter no. (F.6/DFS/MS/2021/EHWZ/76 dated 30.03.2021 Pervious NOC name of Pizza Hut restaurant). The premises was re-inspected by the officers concerned of this department on 08.11.2024 in the presence of Mrs. Rubana (Store Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010. Hence the NOC renewed and premises is fit for occupancy Class-D (Assembly) for G-91, Gr. floor only with effect from 22/11/2024. for a period of 03 (Three) years in accordance with rule 3 6 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/11/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:-

1. MHA Portal ID-2024102215998 dated 22.10.2024.

OC
NY

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

N/32

INSPECTION REPORT

1. Name & address of the building	M/s Jubilant Food Works Limited Dominos Pizza Shop No.G-91, Gr. floor, Plot No.17, District Centre, Manglam Place, Sector-3, Rohini, Delhi-110085. Previously name of Pizza Hut restaurant			
2. Type of Occupancy	Assembly (Eating House)			
3. Type of Case	Renewal (Jubilant Food Works is running at Shop No.G-91, Gr. floor, Plot No.17)			
4. Details of Previous NOC	(F.6/DFS/MS/2021/EH/WZ/76 dated 30.03.2021- Pervious NOC name of Pizza Hut restaurant)			
5. Mall NOC	F.6/DFS/MS/2024/WZ/533 dated 02.09.2024, B+G+ 03 floors			
6. Fire Safety directives letter No	NBC Part 4			
7. Date of inspection	08.11.2024			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
9. Name and designation of officers From the building side	Mrs. Rubana (Store Manager)			
10. Year of Construction	2000			
11. Applicant's letter No.	Online application No.2024102215998dated 22.10.2024			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC	Provided at site	Remarks MR/NMR
1.	Access to building	[Provided & Maintained by Mall management]		
	• Road width	Restaurant within Mall	As Above	NA
	• Gate width	Restaurant within Mall	As Above	NA
	• Width of internal road	Restaurant within Mall	As Above	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Restaurant within Mall	As Above	NA
	• Basements	Restaurant within Mall	As Above	NA
	b. Width of staircases			
	• Upper Floor	Restaurant within Mall	As Above	NA
	• Basements	Restaurant within Mall	As Above	NA
	c. Protection of exits			
	• Fire check door	Restaurant within Mall	As Above	NA
	• Pressurization	Restaurant within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	02 exit	2 x 1.5m	MR
3.	Compartmentation			
	• Fire check door	Restaurant within Mall	As Above	NA
	• Sealing of electrical shafts	Restaurant within Mall	As Above	NA
	• Fire Rating of shaft door	Restaurant within Mall	As Above	NA
	• Water Curtain	Restaurant within Mall	As Above	NA
	• Fire Dampers	Restaurant within Mall	As Above	NA
4.	Smoke Management System			
	a) Basements	30 a/c per hour	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	04nos.	05nos.	MR
	• Types	ABC/CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

(Handwritten signature)

[Provided & Maintained by Mall management]				
6.	First-Aid Hose Reels	01	Provided	MR
	• Total numbers on each floor		Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
[Provided & Maintained by Mall management]				
7.	Automatic fire detection and alarming system	Required	Provided	MR
	a) Type of detectors	-NA-	As Above	-NA-
	b) Location of Main Panel	-NA-	As Above	-NA-
	c) Location of Repeater Panel	-NA-	As Above	-NA-
	d) Alternate source of power	-NA-	As Above	-NA-
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA	-NA-	As Above	-NA-
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basement	-NA-	As Above	-NA-
	• Ground & Upper Floors	-NA-	As Above	-NA-
	• Sprinkler above false ceiling	-NA-	As Above	-NA-
[Provided & Maintained by Mall management]				
11.	Internal Hydrants	1000mm	As Above	MR
	• Size of riser/down-comer		As Above	MR
	• Number of hydrants per floor	01 near to restaurant	As Above	MR
	• Hose Box	01 near to restaurant	As Above	MR
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
[Provided & Maintained by Mall management]				
	Terrace level			
	➤ Discharge of pump	-NA-	As Above	MR
	➤ Head of the pump	-NA-	As Above	MR
	➤ Power Supply	Required	As Above	MR
	➤ Auto Starting of pump	Required	As Above	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	As Above	-NA-
	➤ Draw-off connection	-NA-	As Above	-NA-
	➤ Fire service inlet	-NA-	As Above	-NA-
	➤ Access to tank	-NA-	As Above	-NA-
	• Overhead Tank capacity	-NA-	As Above	-NA-
		Required	Provided	MR
15.	Exit Signage.			
[Provided & Maintained by Mall management]				
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-

24

2/34

Management
MR
MR
MR

	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	As Above	MR
18.	Refuge Area.	[Provided & Maintained by Mall management]		
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room	[Provided & Maintained by Mall management]		
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 464 dated 21.10.2024, the FSC issued vide letter no. F.6/DFS/MS/2021/EHWZ/76 dated 30.03.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Ajay Kumar Sharma
13/11/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO(N/W)

Ajay Kumar Sharma
14/11/2024

By CFO (02)

Ajay Kumar Sharma
18/11/2024

DCFO/456/M21A
Dated...18/11/24.....

CFO
Ajay Kumar Sharma
18/11/2024

Director
Ajay Kumar Sharma
18/11/24

Director
Ajay Kumar Sharma
18/11/24

FT letter to put up
for kind signature
Please.

Ajay Kumar Sharma

Ajay Kumar Sharma
12/11/24

uploaded