

c/27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

NEW DELHI

No. F6/DFS/MS/School/WZ/2024/ 1138

Dated: 26 / 11 / 2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School No-1, (School ID-1514012) Located at Khyala, New Delhi-110018, Two blocks are comprised of ground + 01 Upper Floor & Two blocks are comprised of ground floor only, owned/occupied by Govt. Girls Sr. Sec. School No-1, was already issued FSC by this department vide letter No. F6/DFS/MS/School/MN/2021/664 dated 27/08/2021. The premises was re - inspected by the officer concerned by this department on 13/11/2024 in the presence of Smt. Rasmeet Kaur (Principal) and found that the fire safety arrangements/ equipments provided in the building found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with the circular No. F-16/Estate/CC/Fire safety/2011/3298-3398 dated 01/03/2011 and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 26.11.2024 for a period of three years subject to the conditions mentioned below.

Issued on 26.11.2024 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal, Govt. Girls Sr. Sec. School No-1, Khyala (School ID-1514012) Located at Khyala, New Delhi-110018, Email Id- ggssskhyala1514012@gmail.com
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

11/12

INSPECTION REPORT

1. Name & address of the building	Govt. Girls Sr. Sec. School No-1, Khyala, New Delhi-110018, (School ID- 1514012)			
2. Type of Occupancy	Educational Four blocks (Two Blocks Ground floor only & Two block are ground + One Upper Floor)			
3. Type of Case	Renewal			
4. Details of previous NOC	F6/DFS/MS/School/MN/2021/664 dated 27/08/2021			
5. Fire Safety directives letter No	DOE circular No 3298-3398 dated 01/03/2011			
6. Date of inspection	13/11/2024			
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)			
8. Name and designation of officers from the building side	Smt. Rashmeet Kaur (Principal)			
9. Year of Construction	1976 (As per Previous Inspection report dtd 18/08/2021)			
10. Applicant's letter No.	Email dated 04/11/2024, 25/10/2024 & 24/10/2024			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts each	Block 1 = 2X150cms, Block 2= 1X150 cms including railing	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5 Mtr.	Provided	MR
	g. Door Size	1m	2x1 m Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	07 nos.	Provided	MR
	• Types	CO ₂ , ABC type	5 ABC, 2 CO ₂	MR
	• IS marking	ISI marked	Provided	MR

SV

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA

NA
NA
NA

Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/MN/2021/664 dated 27/08/2021, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~24020/21/2~~

[Signature]
20/11/2024

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

DCFOI...459...002
Date...20/11/2024

[Signature]
20/11/2024

~~CFI~~
~~21/11/2024~~
~~Director~~
~~20/11/2~~

[Signature] Sir, F.T is put up for your kind perusal & signature please.

~~Director~~
~~20/11/2~~

[Signature]
22/11/2024