



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/ 682

Dated: 22/11/2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Luxmi Super Services** (Retail outlet of HPCL Petroleum Class A & B), Laxmi Bai Nagar, Opp. INA Market, New Delhi, comprised of **ground floor only** was issued No Objection Certificate by this department vide letter No. F.5/(12)/DFS/2006/361 dated 22/09/2006. The premises was re-inspected by the officer concerned of this department on 14/11/2024 in the presence of Sh. Nityanand Dobhal (Manager) and observed **CNG facility** (having 01 Cascade at ground level, 01 Compressor units & 02nos Dispensing units) fully commissioned. The fire safety arrangements provided for CNG facility & Petrol Pump were found in working order. Therefore, the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with OISD/rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Hazardous Group J**" with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on 22/11/24 at New Delhi by

  
(ATUL GARG)  
DIRECTOR

T. No. 011 23414000

Copy to: -

1. M/s Luxmi Super Services (Retail outlet of HPCL Petroleum Class A & B), Laxmi Bai Nagar, Opp. INA Market, New Delhi-110023
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate**

1. "No Smoking" and "Not to use Mobile Phone" sign boards should be displayed in such a manner as to be easily readable by all persons.
2. No trade susceptible to cause ignition of petroleum vapor by generating heat, mechanical/electric spark should be allowed within the premises and its vicinity.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the employee's working at the Petrol/CNG pump must know the correct method of operation of fire extinguishers/firefighting.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1	Name & Address of the Building	M/s Luxmi Super Services (Retail outlet of HPCL Petroleum Class A & B), Laxmi Bai Nagar, Opp. INA Market, New Delhi.		
2	Type of Occupancy	Petrol Pump & CNG Filling Station		
3	Building Comprised of	Ground floor only.		
4	Type of Case	Renewal/Addition of CNG		
5	Details of Previous NOC	F.5/(12)/DFS/2006/361 dated 22/09/2006		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14/11/2024		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Nityanand Dobhal (Manager)		
10	Year of construction	1990-91		
11	Applicant letter received through	Outdoor Diary No. 8719 dated 06/11/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement As Per OISD	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	12 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	a) Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management System.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	ISI marked	DCP (50kg)-01, (10kg)-06,	MR
	• Types		CO <sub>2</sub> (22kg)-02, (4.5kg)-03,	MR
	• ISI Marking		ABC (5kg)-06	MR
			Provided	
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-

88

7. Automatic fire detection & alarming system.				
		Gas detector in compressors	Provided & portable gas detector with staff	MR
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	Required	Technician room	MR
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground floor.	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	-NA-	-NA-	-NA-
15.	No Smoking Signage (In Hindi & English)	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	Provided	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risk, if any.	-NA-	1. CO <sub>2</sub> flooding system connected through detectors in compressor unit 2. Fire buckets filled with loose dry sand	-NA-

Note: CNG facility at the existing petrol pump was issued NOC by this department vide letter No. F.5/(3A)/DFS/2010/223 dated 21/07/2010 subject to final clearance. The owner/occupier has submitted valid CNG License issued by Chief Controller of Explosives and Petroleum License issued by Dy. Controller of Explosives (copy enclosed). Accordingly, we may consider the addition of CNG facility at existing petrol pump, if agreed please.

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules/OISD, the NOC issued vide letter No. F.5/(12)/DFS/2006/361 dated 22/09/2006, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended with addition of CNG filling facility.

Accordingly, DFA is put up for approval and signature please.

*Santosh Kumar*  
18.11.24

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD) *[Signature]* 18/11/24  
CFO (RCS) *[Signature]*  
19/11/2024  
Director *[Signature]* 19/11/24  
ADO (SJ)

Sir, F.T letter is pending for your sign. pl

Director *[Signature]* 20/11/24

*Santosh Kumar*  
21/11/24