



No. F6/DFS/MS/SZ/2024/ 687

Dated: 25/11/2024

FIRE SAFETY CERTIFICATE

Certified that the Metro station, Dwarka more ,DMRC, New Delhi 110059, comprised of Ground, + 01 Upper Floor was issued FSC vide letter No. F6/DFS/MS/SZ/2021/638 dated 27-12-2021. The premises was inspected by the officer concerned of this department on 05-11-2024 in the presence of Sh. Sanyam Jain (Manager Fire)) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D – 7 (Except PD Area) with effect from 25/11/2024.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/11/2024... at New Delhi by.

(Anil Garg)
Director,
Delhi Fire Service

Copy to:

1. Sh. Rajesh Aggarwal GM/E&M, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi – 110001.
2. The Authorized Signatory, Metro station, Dwarka more ,DMRC, New Delhi 110059.

Condition for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement if any shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1/12

INSPECTION REPORT

1. Name & address of the building : Metro station, Dwarka more, DMRC, New Delhi 110059.
2. Type of Occupancy : Assembly (D - 7)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SZ/2021/638 dated 27-12-2021
5. Fire Safety directives Letter No. : NBC/ requirements
6. Date of inspection : 05-11-2024
7. Name of the Inspecting Officer : Udai Vir Singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Sanyam Jain (Manager Fire)
9. Year of Construction : 2006
10. Applicant's letter No. : DMRC/03/2024/27. Dated 09/10/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/4, N/5 & N/6	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required 04 (concourse to platform) 02 ground to concourse		MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Required	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	2 mtr	Provided old case	MR
	f. Door Size	1.5 m	Provided old case	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Required CO2 & Water Required	34 Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 nos each platform and 02 nos at ground floor 45 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required Required Required Required	Smoke Provided at SCR Provided at station exit side DG set Provided Provided at platform and concourse level	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150mm Required Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Concourse Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	All the pumps are connected with generator also		
		1800 lpm	Provided	MR
		60m	Provided	MR
		01	Provided	MR
		180 lpm	Provided	MR
		60m	Provided	MR
		1800 lpm	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Fire water tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	Required Required Required Required NA	50 KL at terrace level Provided Provided Provided NA	MR MR MR MR NA

		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Auto and manual CO2 trace tube flooding system is provided for HT/LT electrical panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/SZ/2021/638 dated 27-12-2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:-

1. The fire water tank of 50KL has been provided at Terrace level instead of ground level.
2. Main pump & Stand by pump of 1800 LPM with 60 mtr head & Jockey pump of 180 LPM are provided at concourse level.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation AEO/DW

[Handwritten signature]
 11/11/24

[Handwritten signature]
 11/11/24
 Director

[Handwritten signature]