

C 31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 1148

Dated: 29/11/2024

FIRE SAFETY CERTIFICATE

Certified that the **M.C Primary School, Tilak Nagar No.- 3, New Delhi- 110018**, comprised of ground plus one upper floors owned/occupied by M.C.D., was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/880 dated 25.10.2021. The school building was re-inspected by the officer concerned of this department on 22.11.2024 in the presence of Mrs. Suman Tanwar (In-charge) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Director of Education and that the building/ premises (**ground plus one upper floor only**) is fit for occupancy class "**Educational Building**" w.e.f. 29/11/2024 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 29/11/2024 at New Delhi by.


(Anil Garg)
Director

Delhi Fire Service

Copy to: -

1. The In-charge, M.C Primary School, Tilak Nagar No.- 3, New Delhi- 110018
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

11/16

INSPECTION REPORT

1. Name & address of the building : M.C Primary School, Tilak Nagar No.-3, New Delhi- 110018
2. Building is comprised of : Ground plus one upper floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/880 dated 25.10.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 22.11.2024
8. Name of inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Smt. Suman Tanwar (In-charge)
10. Year of Construction : 2012
11. Applicant's letter No. : Nil dated 14.10.2024

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/BBL requirements | Provided at site | Remarks MR/NMR |
|--------|--|---|------------------------------|-----------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Accessible 06 m 4.5 m N/A | Provided 3.7 m N/A | M/R M/R, old case N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 No.'s | 02 No.'s | M/R |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper Floor | 1.50 m & 0.75 m | 1.40 & 1.20 m | MR, old case |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | e. Width of Corridor | N/A | N/A | N/A |
| | f. Class Room Door Size | 1.0 m | 1.10 m (Double doors) | M/R |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper floors | Required | Natural ventilation provided | M/R |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 08 no's ABC/CO ₂ type ISI marked | Provided | MR |
| | • Types | | Provided | MR |
| | • IS marking | | Provided | MR |

| | | | | |
|-----|--|---|--|---|
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A N/A | N/A N/A | N/A N/A |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity (at terrace) | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 15. | Exit Signage. | N/A | N/A | N/A |

W

N/18

| Provision of Lifts. | | No Lift | | |
|---------------------|---|---------|-----|-----|
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2021/SZ/880 dated 25.10.2021, renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

R.K. Yadav
22/11/2024

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)

ad
26/11/24

CFo/(S2)
thug
26/11/2024

Director
[Signature]
27/11/24

Ado/24