

C-77

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/ 477

Dated : 23/12/2024

FIRE SAFETY CERTIFICATE

Certified that the **Sohana Palace Guest House** located at **2307-8-9 & 1590, 91, 92, 94 & 94 C, Chuna Mandi Main Bazar, Pahar Ganj, New Delhi** comprised of Basement + stilt + Ground + 03 Upper floor, Basement (Storage), stilt - parking , Ground floor (05 guest rooms + reception), 1st floor to 3rd floor (09 guest rooms at each floor) and 4th floor not in use as per affidavit dated 06.02.2020 total 32 guest rooms up to third floor only, owned/occupied by **Sohana Palace Guest House**, was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2022/47ated 25/01/2022. Now, the premises was re-inspected by the officer concerned of this department on 20/11/24 in the presence of Mr. K.M Pandey and found that the said guest house premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the guest house premises is fit for occupancy class Residential, Sub Division-A-1 ground floor (05 guest room), 1st to 3rd floor -09 guest room at each floor total- 32 guest rooms up to third floor only , and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ...23/12/2024...at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy in the building as detailed and deviation if any under intimation to this department .
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi ref. ID NO. 2024110916639 dated 09.11.2024.
3. The Manager, **Sohana Palace Guest House** located at **2307-8-9 & 1590, 91, 92, 94 & 94 C, Chuna Mandi Main Bazar, Pahar Ganj, New Delhi.**

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. **This FSC is valid for guest house up to third floor only.**
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Further, stilt floor and basement shall be used as per conformity of BBL concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as staircase, exits, corridor, etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

11/28
INSPECTION REPORT

1. Name & address of the building:- Sohana Palace Guest House at 2307-8-9, Chuna Mandi & 1590, 91, 92, 94 & 94 C, Main Bazar, Pahar Ganj, Delhi.
2. Type of occupancy:- Residential, Sub Division-A-1
Basement (Storage), Stilt floor -Parking
Ground floor (05 guest rooms),
1st floor to 3rd floor (09 guest rooms at each floor) and
4th floor not in use as per affidavit dated 06.02.20
total 32 guest rooms
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/EH/NDZ/2022/47 dated
25/01/22.
5. Fire safety directives No.- N/A
6. Date of inspection:- 20/11/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Mr. K.M Pandey
9. Year of construction:- 2010
10. Applicant's letter No:- id no. 2024110916639 dated 09.11.2024.

Old Case (renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	N/A	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	01 No. ✓	MR
	2. Basements	01 No.	01 No. ✓	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.5 mtr. ✓	MR
	2. Basements	1.5 mtr.	1.5 mtr. ✓	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	Exhaust fan	MR
	2) Upper floors	Required	Provided/ exhaust fan	MR

5. Fire Extinguishers			
1) Total numbers	10 Nos.	10 Nos.	MR
2) Types	ABC & CO2	ABC & CO2	MR
3) ISI marking	Required	Provided	MR
6. First-Aid Hose Reel			
1) Total number of each floor	01	01	MR
2) Length of hose reel hose	30 mtr.	30 mtr.	MR
3) Nozzle diameter	05 mm	05 mm	MR
7. Automatic Fire Detection & Alarming System			
1) Type of detectors CO	Required	Provided	MR
2) Location of main panel	Gr. floor	Provided	MR
3) Location of repeater panel	N/A	N/A	N/A
4) Alternate source of power	Required	Provided	MR
5) Hooter's Location	Gr. floor	Provided	MR
8. MOEFA	Required	Provided	MR
9. Public Address System	Required	Provided	MR
10. Automatic Sprinkler System			
1) Basement	N/A	N/A	N/A
2) Upper floors	N/A	N/A	N/A
3) Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants			
1) Size of riser/down-comer	N/A	N/A	N/A
2) Number of hydrants per floor	N/A	N/A	N/A
3) Hose box	N/A	N/A	N/A
12. Yard Hydrants			
1) Total number of hydrants	N/A	N/A	N/A
2) Hose box	N/A	N/A	N/A
13. Pumping Arrangement			
1) Ground level	N/A	N/A	N/A
a) Discharge of main pump	N/A	N/A	N/A
b) Head of main pump	N/A	N/A	N/A
c) Number of main pump	N/A	N/A	N/A
d) Jockey pump out put	N/A	N/A	N/A
e) Jockey pump head	N/A	N/A	N/A
f) Stand by pump output	N/A	N/A	N/A
g) Stand by pump head	N/A	N/A	N/A
h) Auto starting/Manual stopping	N/A	N/A	N/A
2) Terrace level			
a) Discharge of pump	450 LPM	450 LPM	MR
b) Head of pump	30 mtr.	30 mtr.	MR
c) Power supply	Required	Provided	MR
d) Auto starting of pump	Required	Provided	MR
14. Captive Water Storage for Fire Fighting			
1) Under ground tank capacity	N/A	N/A	N/A
a) Draw-off connection	N/A	N/A	N/A
b) Fire service inlet	N/A	N/A	N/A
c) Access to tank	N/A	N/A	N/A

	d) Over head tank capacity	10,000 ltr.	10,000 ltr. ✓	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The above fire protection systems provided in the building as per building plan upload and apply for renewal, were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. F6/DFS/MS/EH/NDZ/2022/47 dated 25/01/22, under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, DFA is prepared and put up for kind perusal/approval please.


Signature of the Inspecting Officer



Name: - Ravinder Singh
Designation: - ADO (CC)

DO (CD)


25/11/24


Dy. C.F.O (NDZ)


26/11/24


C.F.O


27/11/24


A044