

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/ 1162

Dated: 05/12/2024

FIRE SAFETY CERTIFICATE

Certified that the **New Galaxy Public School** at E-Block, Qutub Vihar, Ph-1, Plot No. 4, Near Dawarka Sec- 19, New Delhi-110071, comprised of ground floor plus one upper floor, owned/occupied by New Galaxy Public School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2016/SZ/343 dated 03.03.2016 (for ground floor only). The School building was re-inspected by the officer concerned of this department on 25.11.2024 in the presence of Sh. Sudhir Singh (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Director of Education and that the building/ premises (**ground and first floor only**) is fit for occupancy class "**Educational Building**" w.e.f. 05/12/2024 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 05/12/2024 at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service
 7/11/24

Copy to: -

1. The Manager, New Galaxy Public School at E-Block, Qutub Vihar, Ph-1, Plot No. 4, Near Dawarka Sec- 19, New Delhi-110071.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.
3. Executive Engineer (Bldg.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027. : - for information please.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

13

INSPECTION REPORT

1. Name & address of the building : New Galaxy Public School, Plot No. 04, E-Block, Qutub Vihar, Ph-1, Sector-19, Najafgarh, New Delhi-110071.
2. Type of Occupancy : Educational
3. Building comprised of : School running at Ground and first floor only (one store room at 2nd floor)
4. Type of Case : New/addition/alteration
5. Details of Previous NOC : F.6/DFS/MS/School/2016/SZ/343 dated 03.03.2016 (for ground floors only)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 25.11.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Sudhir Singh (Manager)
10. Year of Construction : Ground floor- 2009 & 1st floor- before 2015.
11. Applicant's letter No. : Nil dated Nil, Outdoor dairy No.8653 dated 05.11.2024

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirement | Provided at site | Remarks MR/NMR |
|--------|---|---|---|---------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | 06 m 4.5 m N/A | Provided 4.6 & 2.4 m N/A | M/R M/R N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 02 No.'s N/A | 03 No.'s N/A | M/R N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | 1.50 m & 0.75 m N/A | 1.50 m (2 nos.) & 1.0 m (1 nos.) N/A | M/R N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | N/A N/A | N/A N/A | N/A N/A |
| | d. No. of continuous staircases to terrace | Required | One | M/R |
| | e. Width of Corridor | 1.50 m | 1.50 m | M/R |
| | f. Door Size | 1.0 m | 1.0 m | M/R |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | N/A Required | N/A Natural ventilation provided | N/A M/R |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 10 no's ABC/CO ₂ type ISI marked | Provided Provided Provided | MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | N/A N/A N/A | 01 Nos. 30 m 05 mm | N/A N/A N/A |

N/14

| | | | | |
|-----|---|----------|----------|----------------|
| 7. | Automatic fire detection and alarming system | | | |
| | | N/A | N/A | N/A |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | | N/A | N/A | N/A |
| | • Basement | N/A | N/A | N/A |
| | • Ground Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | | N/A | N/A | N/A |
| | • Size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | | N/A | N/A | N/A |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power Supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | | N/A | N/A | N/A |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | No Lift |
| | | N/A | N/A | N/A |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |

17/15

| | | | | |
|-----|---|-----|-----|-----|
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011, issued by the Director of Education, it's recommended to grant Fire Safety Certificate.

Note: - Earlier Fire Safety Certificate issued by this department vide latter No. F.6/DFS/MS/School/2021/SZ/641 dated 24.08.2021, for ground floor only. But now the school management constructed first floor and one store room at second floor but school running at ground and first floor.

R.K. Yadav
 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (South West)
AS
 29/11/24

CFD(S2)
Handwritten signature
 29/11/2024

Director
Handwritten signature
 29/11/24