



No. F6/DFS/MS/2024/School/ 1165

Dated: 05/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya located at Nehru Kutiya, Malka Ganj, Delhi- 110007 comprised of Ground & First Floors owned/occupied by Nigam Pratibha Vidyalaya was granted FSC by this department vide letter no. F6/DFS/MS/School/2021/68 dated: 24.01.2021. The premises was inspected by the officer concerned of this department on 22.11.2024 in presence of Smt. Nirmala Malik (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational for Ground & first floor only" with effect from05./12./2024 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...05./12./2024 at New Delhi by

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.
2. The Principal, Nigam Pratibha Vidyalaya located at Nehru Kutiya, Malka Ganj, Delhi- 110007.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M.C Primary School at Nehru Kutiya, Malka Ganj, Delhi-110007.
2. Type of Occupancy : Educational
3. Composition of building : Ground & First floor
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2021/68 Dated: 24.01.2021
6. Fire Safety directives letter No : Director of Education Circular Dated: 01.03.2011
7. Date of inspection : 22.11.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mrs. Nirmala Malik (Principal)
10. Year of Construction : 2011
11. Applicant's letter No. : Online E-Mail dated: 18.11.2024


	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			MR
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	02	02	NA
	• Basements	NA	NA	NA
	b. Width of staircases			MR
	• Upper Floors	1.50m	1.65m each	NA
	• Basements	NA	NA	NA
	c. Protection of exits			NA
	• Fire check door	NA	NA	NA
	• Pressurization	01	02	MR (being old case)
	d. No. of continuous staircases to terrace	2m	2.20m	MR
e. Width of Corridor	01m	1.05m double door	MR	
f. Door Size				
3	Compartmentation.			NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			NA
	• Basements	NA	NA	MR
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			MR
	• Total numbers	06nos	08nos	MR
	• Types	ABC/Co2	ABC-08	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	Required	Provided	MR


16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			
	N/A	N/A	N/A	


The fire protection systems provided in the building were tested/ checked randomly and found working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular, the FSC issued vide letter of even no.F6/DFS/MS/School/2021/68 dated 24.01.2021 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended


 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

D.B. Mukharjee (DO/NW)


 02/12/2024
 Dy. Insp. (W2)


 03/12/2024


 3/12/2024
 Director

 3/12/24


 11/02/24

DCFOI... 7657110
 Dated... 3/12/2024