

C31



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/School/ 1166

Dated: 05/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that Sarvodaya Vidyalaya located at Dr. Mukherjee Nagar, Delhi-110009 comprised of Ground & 03 upper floors owned/ occupied by Sarvodaya Vidyalaya was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/School/2020/335 dated 09.09.2020. The premise was re-inspected by the officer concerned of this department on 22.11.2024 in the presence of Sh. Jagdish (Teacher) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under Educational "Group B" with effect from ..05/12/2024 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ....05/12/2024 at New Delhi

  
(Atul Garg)  
Director  
Ph:-011-23414000  
ofc

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, Sarvodaya Vidyalaya located at Dr. Mukherjee Nagar, Delhi-110009.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Sarvodaya Vidyalaya at Dr. Mukherjee Nagar, Delhi-110009.  
 2. Type of Occupancy : Educational  
 3. Type of Case : Renewal  
 4. Composition of building : Ground & 03 upper floors  
 5. Details of previous NOC : F6/DFS/MS/School/2020/335 Dated 09.09.2020  
 6. Fire Safety directives letter No : Nil  
 7. Date of inspection : 22.11.2024  
 8. Name of the Inspecting Officers : ADO (RN)  
 9. Name and designation of officers from the building side : Sh. Jagdish (Teacher)  
 10. Year of Construction : 2017  
 11. Applicant's letter No. : Online E-mail I.D dated: 20.11.2024


|   | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Part-IV/UBBL-2016 Requirements | Provided at site    | Remarks MR/NMR |
|---|---|------------------------------------|---------------------|----------------|
| 1 | <b>Access to building</b>                                   |                                    |                     |                |
|   | • Road width  | Accessible                         | Accessible          | MR             |
|   | • Gate width  | Accessible                         | Accessible          | MR             |
|   | • Width of internal road                                    | NA                                 | NA                  | NA             |
| 2 | <b>Number, Width, Type &amp; Arrangement of Exits</b>       |                                    |                     |                |
|   | a. Number of staircases                                     |                                    |                     |                |
|   | • Upper Floors  | 02                                 | 05                  | MR             |
|   | • Basements   |                                    |                     |                |
|   | b. Width of staircases                                      |                                    |                     |                |
|   | • Upper Floors  | 1.50m                              | 1.70m each          | MR             |
|   | • Basements   | NA                                 | NA                  | NA             |
|   | c. Protection of exits                                      |                                    |                     |                |
|   | • Fire check door   | NA                                 | NA                  | NA             |
|   | • Pressurization  | NA                                 | NA                  | NA             |
|   | d. No. of continuous staircases to terrace                  | 05                                 | 05                  | MR             |
|   | e. Width of Corridor  | Required                           | Provided            | MR             |
|   | f. Door Size  | 01m                                | 1.10m               | MR             |
| 3 | <b>Compartmentation.</b>                                    |                                    |                     |                |
|   | • Fire check door   | NA                                 | NA                  | NA             |
|   | • Sealing of electrical shafts                              | NA                                 | NA                  | NA             |
|   | • Fire Rating of shaft door                                 | NA                                 | NA                  | NA             |
|   | • Water Curtain   | NA                                 | NA                  | NA             |
|   | • Fire Dampers  | NA                                 | NA                  | NA             |
| 4 | <b>Smoke Management System.</b>                             |                                    |                     |                |
|   | • Basements   | NA                                 | NA                  | NA             |
|   | • Upper floors  | Required                           | Natural Ventilation | MR             |
| 5 | <b>Fire Extinguishers</b>                                   |                                    |                     |                |
|   | • Total numbers   | 20nos                              | 30nos               | MR             |
|   | • Types   | ABC/Co2                            | ABC-20/Co2-10       | MR             |
|   | • ISI marking   | ISI Marked                         | Provided            | MR             |

| N/15   |   |               |   |                      |    |
|--|---|---------------|---|----------------------|----|
| 6  | <b>First-Aid Hose Reels.</b>  |               |   |                      |    |
|  | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>  | 03 each floor | 05 each floor                                   | MR                   |    |
|  |   | 30m           | 30m   | M                    |    |
|  |   | 5mm           | 5mm   | MR                   |    |
| 7  | <b>Automatic fire detection and alarming system.</b>  |               |   |                      |    |
|  | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>   | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
| NA   |   | NA            | NA  |                      |    |
| 8  | <b>MOEFA</b>  |               |   | NA                   |    |
| 9  | <b>Public Address System.</b>   |               |   | NA                   |    |
| 10   | <b>Automatic Sprinkler System.</b>  |               |   |                      |    |
|  | <ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>  | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
| NA   |   | NA            | NA  |                      |    |
| 11   | <b>Internal Hydrants</b>  |               |   |                      |    |
|  | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>  | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
| NA   |   | NA            | NA  |                      |    |
| 12   | <b>Yard Hydrants.</b>   |               |   |                      |    |
|  | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>  | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
| NA   |   | NA            | NA  |                      |    |
| 13   | <b>Pumping Arrangements.</b>  |               |   |                      |    |
|  | <ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul> | N/A           | N/A   | N/A                  |    |
|  |   | N/A           | N/A   | N/A                  |    |
|  |   | N/A           | N/A   | N/A                  |    |
|  |   | NA            | NA  | NA                   |    |
|  |   | NA            | NA  | NA                   |    |
|  |   | N/A           | N/A   | N/A                  |    |
|  |   | N/A           | N/A   | N/A                  |    |
|  |   | N/A           | N/A   | N/A                  |    |
|  |   | 450 LPM       | 450 LPM each                                    | MR                   |    |
|  |   | 40m           | 40m   | MR                   |    |
|  |   | Required      | Provided  | MR                   |    |
|  |   | Required      | Provided  | MR                   |    |
|  |   | 14            | <b>Captive Water Storage for fire fighting.</b> |                      |    |
| <ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul> |   |               | NA  | NA                   | NA |
|  | NA  |               | NA  | NA                   |    |
|  | NA  |               | NA  | NA                   |    |
|  | NA  |               | NA  | NA                   |    |
|  | 10,000 LTR  |               | 10,000 LTR                                      | MR                   |    |
|  | 10,000 LTR  | 10,000 LTR    | MR  |                      |    |
| 15   | <b>Exit Signage.</b>  |               |   | Required Provided MR |    |


|    |  |          |          |     |
|----|--|----------|----------|-----|
| 16 | <b>Provision of Lifts.</b>   |          |          |     |
|    | • Pressurization of Lift Shaft   | N/A      | N/A      | N/A |
|    | • Pressurization of Lift lobby   | N/A      | N/A      | N/A |
|    | • Communication In lift Car  | N/A      | N/A      | N/A |
|    | • Fireman's Grounding Switch   | N/A      | N/A      | N/A |
|    | • Lift Signage   | N/A      | N/A      | N/A |
| 17 | <b>Standby power supply</b>  | Required | Provided | MR  |
| 18 | <b>Refuge Area.</b>  |          |          |     |
|    | ➤ Total Area   | N/A      | N/A      | N/A |
|    | ➤ Location   | N/A      | N/A      | N/A |
| 19 | <b>Fire Control Room</b>   |          |          |     |
|    | • Detector System Panel  | N/A      | N/A      | N/A |
|    | • Flow Switch Panel  | N/A      | N/A      | N/A |
|    | • PA System Panel  | N/A      | N/A      | N/A |
|    | • Batter backup  | N/A      | N/A      | N/A |
|    | • Building Floor Plans   | N/A      | N/A      | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A      | N/A      | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2023/School/452 dated 04.10.2023.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4/UBBL-2016, the FSC issued vide letter of even no. F6/DFS/MS/School/2020/335 Dated: 09.09.2020 renewal under rule 37 of the Delhi Fire Service Rules, 2010.

  
 Signature of the Inspecting Officer  
 Name :-C.L. Meena  
 Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

  
 02/12/2024  
 Dy. C.O. (W2)

  
 21/12/2024

  
  
 13/12/2024  
 Director  




DDFD/761/110  
 31/12/2024