



**FIRE SAFETY CERTIFICATE**

Certified that the M/s East Delhi Diner (EDD Hospitality LLP) running at first floor only, located at F – 104, V3S Mall, Laxmi Nagar, Delhi - 110092, building comprised of Basement + Ground + 04 upper floors Restaurant is running at first floor only owned/occupied by EDD Hospitality LLP was issued FSC vide letter No. F6/DFS/MS/EH/NDZ/2021/387 dated 31/12/2021. The premises was re-inspected by the officer concerned of this department on 19.11.2024 in presence of Mr. Vishnu Pandey (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group - D “Assembly Building” Restaurants running at first floor only and valid up to 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 05/12/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to:-**

1. The Joint Commissioner of Police (Lic.), Ist Floor, P.S Defence Colony, New Delhi - 110024 w.e.f. - MHA portal ID - 2024110516460 dated 06.11.2024.
2. The Manager, M/s East Delhi Diner (EDD Hospitality LLP) running at first floor only located at F – 104, V3S Mall, Laxmi Nagar, Delhi - 110092.

**Conditions for the validity of Fire Safety Certificate**

1. Fire Safety Certificate is valid for first floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

218

## INSPECTION REPORT

1	Name & address of the building	M/s East Delhi Diner (EDD Hospitality LLP) running at first floor only located at F - 104, V3S Mall, Laxmi Nagar, Delhi - 110092.
2	Building is comprised of	Basement + Ground + 04 upper floors FSC issued to V3S Mall vide letter no. F6/DFS/MS/School/NDZ/2023/607 dated 19/12/2023 <b>(Restaurant is running at first floor only)</b>
3	Type of occupancy	Assembly Building
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/EH/NDZ/2021/387 dated 31/12/2021
6	Fire safety directives letter no.	Nil
7	Date of inspection	19.11.2024.
8	Name of the inspecting officers	Ashok Kumar Jaiswal, Divisional Officer / East & Yashwant Singh Meena, A.D.O / Laxmi Nagar
9	Name of the designation of officer from the building side	Mr. Vishnu Pandey (Manager)
10	Year of construction	2006
11	Applicant's letter no.	MHA Application No. 2024110516460 dated 06.11.2024

S.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC-IV/UBBL	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A	Road width	12 meters.	26 meters. MR
	B	Gate width	4.5 meters	4.5 meters MR
	C	Width of internal road	N/A	N/A N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A	Number of staircases		
	a	Upper floor	02 nos.	06 nos. MR
	c	Basement	N/A	N/A N/A
	B	Width of staircases		
	a	Upper floor	2.0 mtrs, 1.5 mtrs & 1.0 mtr.	2.0 mtrs, 1.5 mtrs, 1.8 mtrs & 1.0 mtr. MR
	b	Basement	N/A	N/A N/A
	C	Protection of exits		
	a	Fire check door	N/A	N/A N/A
	b	Pressurization	N/A	N/A N/A
	D	No. of continuous staircases to terrace	N/A	N/A N/A
	E	Width of corridor	1.50 meters	1.50 meters MR
	F	Door size	1.50 meters	02 nos. 1.50 meters MR
	3	<b>Compartmentation:</b>		
A		Fire check door	N/A	N/A N/A
B		Sealing of electrical shafts	N/A	N/A N/A
C		Fire rating of shaft door	N/A	N/A N/A
D		Water curtain	N/A	N/A N/A
E		Fire dampers	N/A	N/A N/A
4	<b>Smoke Management System:</b>			
	A	Basement	N/A	N/A N/A
	B	Upper floor	N/A	N/A N/A

(U) A


<b>5. Fire Extinguisher:</b>				
A	Total numbers	03 nos.	03 nos	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 nos.	01 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	Heat & Smoke	Provided	MR
B	Location of main panel	Control room	1 <sup>st</sup> basement	MR
C	Location of repeater panel	Security room	Provided	MR
D	Alternate source of power	Battery & DG Set	Provided	MR
E	Hooter's Location	Different location	Different location	MR
8	<b>MOEFA:</b>	Required	Provided	MR
9	<b>Public Address System:</b>	Required	Provided	MR
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no	01 no	MR
C	Hose box	01 no	01 no	MR
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	01 no	MR
B	Hose box	N/A	01 no	MR
<b>13 Pumping Arrangements: Provided for V3S Mall</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	2850 LPM	2850 LPM	MR
B	Head of main pump	60 m	60 m	MR
C	Number of main pumps	01 no	01 no	MR
D	Jockey pump out put	180 LPM	180 LPM	MR
E	Jockey pump head	60 m	60 m	MR
F	Standby pump out put	2850 LPM	2850 LPM	MR
G	Standby pump head	60 m	60 m	MR
H	Auto starting /manual stopping	Required	Provided	MR
<b>2 Terrace Level</b>				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A


14	<b>Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	2,00,000 ltrs	2,00,000 ltrs	MR	
B	Draw-off connection	Required	Provided	MR	
C	Fire service inlet	Required	Provided	MR	
D	Access to tank	Required	Provided	MR	
E	Overhead tank capacity	30,000 liters	30,000 liters	MR	
15	<b>Exit Signage:</b>		Required	Provided	MR
16	<b>Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A	
B	Pressurization of lift lobby	N/A	N/A	N/A	
C	Communication in lift car	N/A	N/A	N/A	
D	Firemen's grounding switch	Required	Provided	MR	
E	Lift signage	Required	Provided	MR	
17	<b>Standby Power Supply:</b>		Required	Provided	MR
18	<b>Refuge Area:</b>				
A	Total area	N/A	N/A	N/A	
B	Location	N/A	N/A	N/A	
19	<b>Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A	
B	Flow switch panel	N/A	N/A	N/A	
C	PA system panel	N/A	N/A	N/A	
D	Battery backup	N/A	N/A	N/A	
E	Building floor plans	N/A	N/A	N/A	
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			N/A	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2021/387 dated 31/12/2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

No file is pending with me before disposal of this case.


  
26/11/2024  
Signature of the Inspecting Officer  
Name : Yashwant Singh Meena  
Designation: ADO/LN

  
26/11/2024  
Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: DO /East

~~DY.CFO/NDZ~~

  
27/11/24

C.F.O.

  
28/11/2024

  
27/11/24

  
on leave