

C 25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001


No. F6/DFS/MS/School/2024/SZ/ 1175

Dated: 10/12/2024

FIRE SAFETY CERTIFICATE

Certified that the **J.B.M Public school** running at ground plus two upper floors in a building comprised of ground plus three upper floors located at Nasir Pur New Delhi-110045, owned/occupied by J.B.M Public school was issued Fire Safety Certificate vide letter No. F.6/DFS/MS/school/2021/SZ/1002 dated 10.12.2021. The school building was re-inspected by the officer concerned of this department on dated 28.11.2024 in the presence of Dr. Amit Solanki (Manager) and found that school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**ground plus two upper floors only**) is fit for occupancy class "Educational Building" w.e.f. 10/12/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 10/12/2024 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service
07/12/24

Copy to: -

1. The Manager, J.B.M Public school at Nasir Pur New Delhi-110045.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/18

INSPECTION REPORT

- 1 Name & address of the building : J.B.M Public school, Nasir Pur, New Delhi-110045.
 2. Building is comprised of : G+3 floors but school running at ground plus two upper floor.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/school/2021/SZ/1002 dated 10.12.2021
 6. Fire Safety direction letter No : N/A
 7. Date of Inspection : 28.11.2024
 8. Name of the Inspecting Officers: : ADO R.K. YADAV
 9. Name of the designation of Officer from the building side : Dr. Amit Solanki (Manager)
 10. Year of Construction : 2002 & 2015
 11. Applicant's letter No : Online email Id jbmpschoo@gmail.com dated 21.11.2024

S. No.	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	06 m	MR
	Gate width	4.5 m	Direct accessible from road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	04 Nos.	MR
	Upper Floor	N.A.	N.A.	N.A.
	Basement			
	B. Width of Staircases			
	Upper Floor	1.5 m & .75 m	1.25, 1.20, 1.40 & 1.50 m and 1.5 m (ramp from GF to FF)	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	2 no.	2 no.	MR
	e. No. of continuous staircases to terrace	1.5 m	1.50 m	MR
g. Width of Corridor	1 m	Provided	MR	
h. Door Size				
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural ventilation	MR

N/5

h

5.	Fire Extinguisher			MR
	Total numbers	10 Nos.	12 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	
6	First-aid-Hose Reels.			MR
	Total numbers of each floor	01 no.	Two	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	
7	Automatic fire detection and alarming system.			N.A.
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	MR
8	MOEFA	N.A.	Provided	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			N.A.
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	
11	Internal Hydrants	100 mm	Provided	MR
	size of riser/down-comer	One	Two	MR
	Number of hydrants per floor	N.A.	one	
	Hose Box			
12	Yard Hydrants.	N.A.	N.A.	N.A.
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box			
13	Pumping Arrangements.			N.A.
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
4	Captive Water Storage for Fire Fighting.			N.A.
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10000 Ltrs	Provided	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			N.A.
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.


N/20

17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/school/2021/SZ/1002 dated 10.12.2021, renewal under rule, 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: - As per undertaking given by the Manager of School (placed at C-21) that the school building comprised of ground plus three upper floors but school running at ground plus two upper floors only.


 Signature of the Inspecting Officer
 Name- R. K. Yadav
 Designation- ADO (JKP)

DO (South West)  3/12/24

CFO (S2)


 3/12/2021

Director 
 3/12/24

FT letter is put up for sign please 

DIRECTOR 


 3/12/24