

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/WZ/School/ 1178

Dated: 10/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya, Prahladpur, Delhi-110042, (School ID-1310032), comprised of 02 Blocks, Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2021/School/WZ/936 dated 12.11.2021. The premises was re-inspected by the officer concerned of this department on 20.11.2024 in the presence of Dr. Anjali Khatri (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 10/12/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/12/2024 at New Delhi by

(Atul Garg)  
 DIRECTOR

Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Sarvodaya Kanya Vidyalaya, Prahladpur, Delhi-110042, (School ID-1310032).

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)



**INSPECTION REPORT**

1. Name & address of the building	Sarvodaya Kanya Vidyalaya, Prahladpur, Delhi-110042. (School ID-1310032).
2. Type of Occupancy	Educational
3. Type of Case	Renewal (02 Blocks Ground + 03 upper floor)
4. Details of Previous NOC	F.6/DFS/MS/2021/School/WZ/936 dated 12.11.2021.
5. Fire Safety directives letter No	NBC Part-IV
6. Date of inspection	20.11.2024.
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Dr. Anjali Khatri (Principal)
9. Year of Construction	2021
10. Applicant's letter No.	OD No. 8778 dated 08.11.2024.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	Block-A-03nos. Block-B-02-nos.	Block-A-03-nos. Block-B-02-nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.5m each	Block-A-1.70m x 03 Block-B-1.70m x 02	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	Block-A-03nos. Block-B-02-nos.	Block-A-1.70m x 03 Block-B-1.70m x 02	MR
	<b>e. Width of Corridor</b>	1.50m	Provided	MR
	<b>f. Door Size</b>	1.20m	1.20m double door	MR
3.	<b>Compartmentation</b>	-NA-	-NA-	-NA-
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	c) Basements	-NA-	-NA-	-NA-
	d) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	30nos.	Provided	MR
	b) Types	ABC/CO2	ABC/Co2	MR
	c) IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			

*(Handwritten signature)*

		Block-A-04nos. Block-B-03-nos.	Block-A-04-nos. Block-B-03-nos.	MR
	d) Total numbers on each floor			MR
	e) Length of hose reel hose	30m	Provided	MR
	f) Nozzle diameter	05mm	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	f) Type of detectors	-NA-	-NA-	-NA-
	g) Location of Main Panel	-NA-	-NA-	-NA-
	h) Location of Repeater Panel	-NA-	-NA-	-NA-
	i) Alternate source of power	-NA-	-NA-	-NA-
	j) Hooters' Location	-NA-	-NA-	-NA-
<b>8.</b>	<b>MOEFA</b>			
<b>9.</b>	<b>Public Address System</b>			
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
<b>12.</b>	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	Block-A-450lpm Block-B-450lpm.	Block-A-450lpm x 2 Block-B-450lpm x 2	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	Block-A-10,000ltr Block-B-10,000ltr	Block-A-10,000ltr Block-B-10,000ltr	MR
<b>15.</b>	<b>Exit Signage.</b>			
		Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			




04-nos.  
04-nos.  
M.  
MR  
TA-


a)	Pressurization of Lift Shaft	-NA-	-NA-	-NA-
b)	Pressurization of Lift lobby	-NA-	-NA-	-NA-
c)	Communication In lift Car	-NA-	-NA-	-NA-
d)	Fireman's Grounding Switch	-NA-	-NA-	-NA-
e)	Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2021/School/WZ/936 dated 12.11.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

  
Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)


DO(N/W)

  
02/12/2024

By CPO (102)

  
03/12

DCFO/...7.11.2024  
Dated...3/12/2024

  
3  
Director



Fi letter to put up for kind  
perusal and Signature please.

Director 

  
04/12