



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C/131

No F 6 / DFS / MS / 2024 / WZ / 722

Dated: 10/12/2024

FIRE SAFETY CERTIFICATE

Certified that the **Shopping Mall, Community Centre** located at **A- Block, Shalimar Bagh, New Delhi- 110088** comprised of **Lower Basement, Upper Basement, Ground plus Five upper floors** was issued FSC by this department vide letter No F6/DFS/MS/Mercantile/WZ/2021/549 dated 03.11.2021. The premise was re-inspected by the officer concerned of this department on 20.11.2024 in the presence of **Sh. Abhishek Sharma (Manager)** and found that that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy class " Mercantile & Assembly Building" Group F and Group D with effect from ...10/12/2024... for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...10/12/2024... at New Delhi, by

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Sh. Abhishek Sharma, M/s Shopping Mall, Community Centre located at A- Block, Shalimar Bagh, New Delhi- 110088.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. All the doors, exits and internal road must be kept free from any obstruction.

N-43

INSPECTION REPORT

1. Name & address of the building : Shopping Mall, Community Centre located at A- Block, Shalimar Bagh, Delhi- 110088.
2. Type of Occupancy : Mercantile & Assembly
3. Building Comprised of : Lower Basement, Upper Basement, Ground plus Five Upper Floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/Mercantile/WZ/2021/549 Dated 03/11/2021
6. Fire Safety directives letter No : F6/DFS/MS/BP/2004/2443 Dated 14/10/2004
7. Date of inspection : 20/11/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. Abhishek Sharma (Manager)
10. Year of Construction : 2006 as per N-36
11. Applicant's letter No. : Form J dated 16/10/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/ NBC/ Inspection report dated 14.10.2021	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	10	Provided	MR
	• Basements	16	Provided	MR
	b. Width of staircases			
	• Upper Floor	2 × 2 m & 8 × 1.5 m	Provided	MR(old case)
	• Basements	2 × 2 m & 14 × 1.5 m	Provided	MR(old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	1.5 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	50 Nos.	80 Nos.	MR
	• Types	ABC, Co2 & WCo2	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/ Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Ground Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR

		249		MR
	• Hooters' Location	At strategic location	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			MR
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			MR
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	04	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			MR
	• Total number of hydrants	06	Provided	MR
	• Hose Box	06	Provided	MR
13.	Pumping Arrangements			
	Ground Level			
	➤ Discharge of main Pump	4500 lpm	Provided	MR
	➤ Head of Main pump	60 m	Provided	MR
	➤ Number of main pumps	03	Provided	MR
	➤ Jockey Pump out put	2 × 180 lpm	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	4500 lpm	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	3,00,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided in basement	MR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR

N-45

PA System Panel	Required	Provided	MR
Battery backup	Required	Provided	MR
Building Floor Plans	Required	Provided	MR
Special Fire Protection System for Protection of special Risks, if any:	Required	CO2 flooding in DG Room	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F6/DFS/MS/WZ/2024/595 dated 22/10/2024.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the fire safety certificate issued vide letter number F6/DFS/MS/Mercantile/WZ/2021/549 dated 03/11/2021 under rule 37 of the Delhi Fire Service Rules, 2010.

(Signature)
22/11/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

ADO/B.W.

dy
22/11

CFI
22/11/2024

Director
31/11/24

Sm. A7 letter in photo for sm plan

(Signature)
31/12/24

Director
4/1/25

Ol... 686...
Date... 22/11/2024