

C 25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

No.F.6/DFS/MS/School/2024/SZ/1174

Dated: 10/12/2024

NEW DELHI- 110001

FIRE SAFETY CERTIFICATE

Certified that the **Rajdhani Public School** at Vikas Nagar, Hastal, New Delhi-110059, having four blocks namely A block comprised of ground plus one upper floor, B block comprised of ground floor only, C Block comprised of ground plus three upper floors & D block comprised of ground plus two upper floors, owned/occupied by Rajdhani Public School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/892 dated 27.10.2021. The School building was re-inspected by the officer concerned of this department on 27.11.2024 in the presence of Sh. Umesh Chand Tyagi (Manager) and found that school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational Building" w.e.f. 10/12/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 10/12/2024 at New Delhi.


(Atul Garg)
Director

Delhi Fire Service
2024

Copy to: -

1. The Manager, Rajdhani Public School at Vikas Nagar, Hastal, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Rajdhani Public School, Vikas Nagar, Hastsal, New Delhi-110059
2. Building comprised of : 4 Blocks (A blk=G+1, B blk=ground floor, C blk = G+3 (3rd floor constructed only one room & D blk=G+2 floors)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/892 dated 27.10.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 27.11.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Umesh Chand Tyagi (Manager)
10. Year of Construction : 1996 (Block-A, B & C), 2015 (Block-D)
11. Applicant's letter No. : Online email Id rajdhanipublicschool@yahoo.com dated 24.10.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 4.5 mtrs N/A	08 mtrs Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Block A Block B (Gr. only) Block C & Block D interconnected 	1 No. N/A 3 no.	Provided N/A 3 no.	MR N/A MR
	b. Width of staircases	1.02 M	Provided	MR old accepted
	<ul style="list-style-type: none"> Block A Block B (Gr. only) Block C & Block D interconnected 	N/A 1.5 m each N/A N/A	N/A Provided N/A N/A	N/A MR N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	2 nos.	Provided	MR
	d. No. of continuous staircases to terrace Block C & Block D	1.50 m	Provided	MR
	e. Width of Corridor	1.0 m	Provided	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural Ventilation	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR

❖ Block C & Block D interconnected at each floor level.


6.	First-Aid Hose Reels		
		1 No.	MR
	• Total numbers on each floor	30 m	MR
	• Length of hose reel hose	5 mm	MR
	• Nozzle diameter		
7.	Automatic fire detection and alarming system		
	• Type of detectors	N/A	N/A
	• Location of Main Panel	N/A	N/A
	• Location of Repeater Panel	N/A	N/A
	• Alternate source of power	N/A	N/A
	• Hooters' Location	N/A	N/A
8.	MOEFA	N/A	N/A
9.	Public Address System	N/A	N/A
10.	Automatic Sprinkler System		
	• Basement	N/A	N/A
	• Ground Floor	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A
11.	Internal Hydrants		
	• Size of riser/down-comer	N/A	N/A
	• Number of hydrants per floor	N/A	N/A
	• Hose Box	N/A	N/A
12.	Yard Hydrants		
	• Total number of hydrants	N/A	N/A
	• Hose Box	N/A	N/A
13.	Pumping Arrangements		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby Pump out put	N/A	N/A
	➤ Standby Pump Head	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A
	➤ Pump House Access	N/A	N/A
	• Terrace level		
	➤ Discharge of pump	450 LPM	450 LPM
	➤ Head of the pump	40 m	40 m
	➤ Power Supply	Required	Provided
	➤ Auto Starting of pump	Required	Provided
14.	Captive Water Storage for fire fighting		
	• Underground tank capacity	N/A	N/A
	➤ Draw-off connection	N/A	N/A
	➤ Fire service inlet	N/A	N/A
	➤ Access to tank	N/A	N/A
	• Overhead Tank capacity	10000 ltrs	Provided
15.	Exit Signage.	Required	Provided




N/14

16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2021/SZ/892 dated 27.10.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

D.O. (South West) 
 3/12/24
 CFO (SZ) 
 3/12/2024
 Director 
 3/12/24

