

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/WZ/School/ 1188

Dated: 13/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-Ed Sarvodaya Vidyalaya, Rohini, Sector-22, Delhi-85 (School Id-1412290), comprised of Basement + Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2021/WZ/School/961 dated 26.11.2021. The premises was re-inspected by the officer concerned of this department on 26.11.2024 in the presence of Mr. Ashok Dabas (Estate Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Group B Educational" with effect from 13/12/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/12/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000
OK
MHT

Copy to :-

1. The Principal, Govt. Co-Ed Sarvodaya Vidyalaya, Rohini, Sector-22, Delhi-85 (School Id-1412290).
2. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K'[sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of Rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

| | |
|---|---|
| 1. Name & address of the building | Govt. Co-Ed Sarvodaya Vidyalaya, Rohini, Sector-22, Delhi-85 (School Id-1412290) |
| 2. Type of Occupancy | Educational |
| 3. Type of Case | Renewal (Basement + Ground + 03 upper floors) |
| 4. Details of Previous NOC | F.6/DFS/MS/2021/WZ/School/961 dated 26.11.2021. |
| 5. Fire Safety directives letter No | NBC Part-IV. |
| 6. Date of inspection | 26.11.2024 |
| 7. Name of Inspecting Officer | Sh. Ajay Kumar Sharma (ADO Rohini) |
| 8. Name and designation of officers From the building side | Mr. Ashok Dabas (Estate Officer) |
| 9. Year of Construction | 2017 |
| 10. Applicant's letter No. | Online e-mail dated 13.11.2024 |

| S. No | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|-------|---|-----------------|--------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | As per MPD 2021 | 18m | MR |
| | • Gate width | 4.5m | 6m | MR |
| | • Width of internal road | -NA- | -NA- | -NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 03nos. | 03nos. | MR |
| | • Basements | 02 & 02 ramp | 02 & 02 ramp | MR |
| | b. Width of staircases | | | |
| | • Upper Floor | 1.5m | Provided | MR |
| | • Basements | 2m | Provided | MR |
| | c. Protection of exits | | | |
| | • Fire check door | -NA- | -NA- | -NA |
| | • Pressurization | -NA- | -NA- | -NA |
| | d. No. of continuous staircases to terrace | 02nos. | Provided | MR |
| | e. Width of Corridor | Required | Provided | MR |
| | f. Door Size | -NA- | -NA- | -NA |
| 3. | Compartmentation | | | |
| | • Fire check door | -NA- | -NA- | -NA |
| | • Sealing of electrical shafts | -NA- | -NA- | -NA |
| | • Fire Rating of shaft door | -NA- | -NA- | -NA |
| | • Water Curtain | -NA- | -NA- | -NA |
| | • Fire Dampers | -NA- | -NA- | -NA |
| 4. | Smoke Management System | | | |
| | a) Basements | 30 /c per hour | Exhaust fan | MR |
| | b) Upper floors | 12 a/c per hour | Natural ventilated | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 50nos. | Provided | MR |
| | • Types | ABC/CO2 | ABC/CO2 | MR |
| | • IS marking | ISI marked | Yes | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | 02nos. | Provided | MR |
| | • Length of hose reel hose | 30mm | Provided | MR |
| | • Nozzle diameter | 5m | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | a) Type of detectors | -NA- | -NA- | -NA |

| | | Fire Control | Det |
|-----|--|--------------|------------|
| | b) Location of Main Panel | -NA- | -NA- |
| | c) Location of Repeater Panel | -NA- | -NA- |
| | d) Alternate source of power | -NA- | -NA- |
| | e) Hooters' Location | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- |
| 10. | Automatic Sprinkler System | Required | Provided |
| | • Basement | -NA- | -NA- |
| | • Ground & Upper Floors | -NA- | -NA- |
| | • Sprinkler above false ceiling | -NA- | -NA- |
| 11. | Internal Hydrants | | MR |
| | • Size of riser/down-comer | -NA- | 100mm |
| | • Number of hydrants per floor | -NA- | 03nos. |
| | • Hose Box | -NA- | 03nos. |
| 12. | Yard Hydrants | | -NA |
| | • Total number of hydrants | -NA- | -NA- |
| | • Hose Box | -NA- | -NA- |
| 13. | Pumping Arrangements | | -NA |
| | • Ground Level | -NA- | -NA- |
| | ➤ Discharge of main Pump | -NA- | -NA- |
| | ➤ Head of Main pump | -NA- | -NA- |
| | ➤ Number of main pumps | -NA- | -NA- |
| | ➤ Jockey Pump out put | -NA- | -NA- |
| | ➤ Jockey pump head | -NA- | -NA- |
| | ➤ Standby Pump out put | -NA- | -NA- |
| | ➤ Standby Pump Head | -NA- | -NA- |
| | ➤ Auto Starting/Manual Stopping | -NA- | -NA- |
| | ➤ Pump House Access | -NA- | -NA- |
| | Terrace level | | MR |
| | ➤ Discharge of pump | 900lpm | Provided |
| | ➤ Head of the pump | 40m | 40m |
| | ➤ Power Supply | Required | Provided |
| | ➤ Auto Starting of pump | Required | Provided |
| 14. | Captive Water Storage for fire fighting | | -NA |
| | • Underground tank capacity | -NA- | 100,000ltr |
| | ➤ Draw-off connection | -NA- | -NA- |
| | ➤ Fire service inlet | -NA- | -NA- |
| | ➤ Access to tank | -NA- | -NA- |
| | • Overhead Tank capacity | 15,000ltr | Provided |
| 15. | Exit Signage. | Required | Provided |
| 16. | Provision of Lifts. | | -NA |
| | • Pressurization of Lift Shaft | -NA- | -NA- |
| | • Pressurization of Lift lobby | -NA- | -NA- |
| | • Communication In lift Car | -NA- | -NA- |
| | • Fireman's Grounding Switch | -NA- | -NA- |
| | • Lift Signage | -NA- | -NA- |
| 17. | Standby power supply | -NA- | -NA- |
| 18. | Refuge Area. | | -NA |
| | ➤ Total Area | -NA- | -NA- |
| | ➤ Location | -NA- | -NA- |

Fire Control Room

| | | | |
|---|------|------|------|
| • Detector System Panel | -NA- | -NA- | -NA- |
| • Flow Switch Panel | -NA- | -NA- | -NA- |
| • PA System Panel | -NA- | -NA- | -NA- |
| • Battery backup | -NA- | -NA- | -NA- |
| • Building Floor Plans | -NA- | -NA- | -NA- |
| 20. Special Fire Protection System for Protection of special Risks, if any: | -NA- | -NA- | -NA- |

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2021/WZ/School/961 dated 26.11.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
27.11.24

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

D.B Mukherjee
DO (NW)

[Signature]
02/12/2024

[Signature]
10/2

[Signature]

[Signature]
9/12/2024

[Signature]
16/12/24

[Signature]

AT letter is put up for kind perusal and signature please.

[Signature]
Director

[Signature]
12/12/24

DCFO/... 20.11.2024
Dated... 27/11/2024