

c/68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2024/ 1194

Dated: 16/12/2024

FIRE SAFETY CERTIFICATE

Certified that the building of MBS International School, Located at Sector 11, Dwarka, New Delhi – 110075 comprised of Basement + Ground + 3 Upper Floor was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/School/2020/SZ/267, dated 10/08/2020. The premises was inspected by the officer concerned of this department on 29-11-2024 in the presence of Sh. Atul Wadhawan (Principal) & Sh. Gulshan Kumar (Chairman) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 262 – 362 dated 17/01/2005 and that the premises is fit for occupancy class B “Educational building” with effect from 16/12/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...16.12.2024... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c


Copy to:

1. The Principal, MBS International School, Located at Sector 11, Dwarka, New Delhi – 110075.
2. The, Directorate of Education Old Secretariat Delhi – 110054.

Condition for the validity of fire safety certificate:-

1. The 4th floor shall not be occupied without getting Fire Safety Certificate from this department.
2. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. Basement shall be used strictly as per building bye laws.
10. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/17

INSPECTION REPORT

1. Name & address of the building: MBS International School, Located at Sector 11, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational (Basement + Ground+ 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC:F6/DFS/MS/School/2020/SZ/267, dated 10/08/2020
5. Fire Safety directives L. No. : DOE Cr. No. 262-362 dated 17/01/2005
6. Date of inspection : 29-11-2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
 from the building side : Sh. Atul Wadhawan (Principal) &
 Sh. Gulshan Kumar (Chairman)
9. Year of Construction : 2010
10. Applicant's letter No. : Email dated 21/11/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/09, N/10 & N/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	5 Nos.	5 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	Old Case	MR (Being old case)
	• Basements	1.5 mtr	Old Case	MR (Being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	05 Nos.	05 Nos.	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	12 a/c charge	Exhaust fans provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR

17/11/24

N/18

5.	Fire Extinguishers			
	• Total numbers	18 nos.	Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	03	03	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

11/19

Captive water Storage for fire fighting:				
14.	Under ground tank capacity	NA	NA	NA
	Draw off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10000 ltrs	Provided	MR(Being old case)
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of lift lobby	NA	NA	NA
	Communication in lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	
18.	Refuge Area			
	Total area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire control room			
	Detector system panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2020/SZ/267, dated 8/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved, the FSC may be issued.

Note:- Photographs are placed at C/65 & C/66.

[Signature] 3/12/24
 Signature of the Inspecting Officer
 Name: Udai Vir Singh
 Designation: ADO/DWK

[Signature] 4/12/24

[Signature] 5/12/2024

[Signature]