

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/404

Dated: 12/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of **M/s Bougle** located at Plot No H 5 oblique 3 and 4 **Second Floor**, Back Side Ward No -1, Ambawatta One, Kalka Das Marg, Mehrauli, New Delhi-110030 in the building comprised of Basement, Ground, plus Two Upper floor owned/occupied by A Unit of First Fiddle Ventures LLP was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2021/SZ/364 dated 10/12/2021. The restaurant premise was re-inspected by the officer concerned of this department on 07/12/2024 in the presence of Mr. Daljeet and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant at 2nd floor only)** and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/12/2024 at New Delhi by

(ATUL GARG)
DIRECTOR

DEHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police, Lic/Branch 1st Floor PS Defence Colony, New Delhi 110049 (Ref. MCD Portal ID 2024112917485 dated 29/11/2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

M/7

INSPECTION REPORT				
1	Name & Address of the Building	M/s Bougie (A Unit of First Fiddle Ventures LLP) at Plot No H 5 oblique 3 and 4 Second Floor, Back Side Ward No -1, Ambawatta One, Kalka Das Marg, Mehrauli, New Delhi-110030		
2	Type of Occupancy	Assembly 'Group-D' (Restaurant running at 2 nd Floor only)		
3	Building comprised of	Basement Ground plus Two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2021/SZ/364 dated 10/12/2021		
6	Fire Safety Directives Letter No	UBBL 2016/ NBC Part IV		
7	Date of Inspection	07.12.204		
8	Name of the Inspecting Officers	Rajesh Kumar/ ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Daljeet		
10	Year of construction/ date of conversion	2000		
11	Applicant letter No.	MCD Portal ID 2024112917485 dated 29-11-2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/ NBC Requirement	Provided at Site	Remarks
1	Access to Building.			
	• Road width	06m	12m	MR
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	02 Nos	02 no's	MR
	• Basement floor	-NA-	NA	-NA-
	b. Width of Staircase			
	• Upper floors	1.50m each	2m & 1.50 m	MR
	• Basement floor	-NA-	NA	-NA-
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	02	02	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 Exits 1.5m each	1.50 m each	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	Required	10 Provided	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			

4

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooper's location 	Required	Provided	MR
		Required	Provided	MR
		N/A	NA	N/A
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	NA	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Common with Building		
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump House Access 	2280lpm	Provided	MR
		40m	Provided	MR
		01	Provided	MR
		180 lpm	Provided	MR
		40m	Provided	MR
		2280lpm	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltrs	20,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-

	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2021/SZ/364 dated 10/12/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

RK
9/12/2024

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DO (SD)

Mukherjee
9/12/24

CFD/MS

Wagh
10/12/2024

Director

[Signature]
14/12/24

ADP/BCP

As approved, F.T. letter is put up for your signature pl

[Signature]
11/12/24

Director
[Signature]

M

Upland
16/12/24

[Signature]