

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/EH/2024/SZ/403

Dated:12../12../2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s ECHOES** located at HS-6, **1st Floor**, Kailash Colony Market, New Delhi 110048 comprised of Ground, Mezzanine + Three Upper Floor owned/occupied by A Unit of TAUS Venture have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 05/12/2024 in the presence of Mr. Umesh Sharma found that the said building / premises is fit for occupancy Class **Group-D "Assembly Building"** and **Validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/12/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint C.P (Lic/Branch) First Floor, PS Defence Colony, New Delhi - 110049. (Ref. MCD Portal ID 2024111216705 dated 18/11/2024)

Conditions for the validity of the safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
4. The use of basement shall be strictly in accordance with the provision of UBBL- 2016.
5. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/21

| INSPECTION REPORT | | | | |
|-------------------|---|--|------------------|---------|
| 1 | Name & Address of the Building | M/s ECHOES (A Unit of TAUS Venture) located at HS-6, 2 nd Floor, Kailash Colony Market, New Delhi | | |
| 2 | Type of Occupancy | Assembly 'Group-D' (Restaurant at 1 st Floor) | | |
| 3 | Building comprised of | Ground, + Mezz. + Three Upper floors | | |
| 4 | Type of Case | New Case | | |
| 5 | Details of Previous NOC | Nil | | |
| 6 | Fire Safety Directives Letter No | I/BRI. 2016/ NBC Part IV | | |
| 7 | Date of Inspection | 05/12/2024 | | |
| 8 | Name of the Inspecting Officers | ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Umesh Sharma | | |
| 10 | Year of construction/ date of conversion | 1975 | | |
| 11 | Applicant letter No. | MCD Portal ID 2024111216705 dated 18/11/2024 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | UBBL/ NBC Requirement | Provided at Site | Remarks |
| 1 | Access to Building. | | | |
| | • Road width | 06m | Provided | MR |
| | • Gate width | NA | NA | -NA- |
| | • Width of internal road | NA | NA | -NA- |
| 2 | Number, width, type & arrangement of exits | | | |
| | a. Number of Staircase | | | |
| | • Upper floors | 02 Nos | 02 no's | MR |
| | • Basement floor | -NA- | NA | -NA- |
| | b. Width of Staircase | | | |
| | • Upper floors | 1.50 m each | 1.50 mtr each | MR |
| | • Basement floor | -NA- | NA | -NA- |
| | c. Protection of exits | | | |
| | • Fire check door | -NA- | NA | -NA- |
| | • Pressurization | -NA- | NA | -NA- |
| | d. No. of continuous staircase to terrace | 01 | 01 | MR |
| | e. Width of corridor | N/A | N/A | N/A |
| | f. Door size | 1.5mtr each | 1.50 mtr each | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | N/A | N/A | N/A |
| | • Sealing of electrical shafts. | N/A | N/A | N/A |
| | • Fire rating of shaft door. | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire dampers. | N/A | N/A | N/A |
| 4 | Smoke Management system. | | | |
| | • Basement | 30 ACPH | N/A | N/A |
| | • Upper floors | 12 ACPH | N/A | N/A |
| 5 | Fire Extinguishers. | | | |
| | • Total numbers | 04 Nos | 04 Provided | MR |
| | • Types | ABC / CO2 | ABC & Co2 | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6 | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | One | Provided | MR |
| | • Length of hose-reel hose. | 30m | Provided | MR |
| | • Nozzle Diameter | 5mm | Provided | MR |
| 7 | Automatic fire detection & alarming system. | | | |
| | • Type of detectors | Required | Provided | MR |
| | • Location of Main Panel | Required | Provided | MR |
| | • Location of Repeater Panel | N/A | NA | N/A |

N/22

| | | | | |
|----|--|------------|----------|------|
| | <ul style="list-style-type: none"> • Alternate source of power • Hooper's location | Required | Provided | MR |
| | | Required | Provided | MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System | -NA- | NA | -NA- |
| 10 | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> • Basement | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper floors | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> • Size of Riser/Down-comer | Required | Provided | MR |
| | <ul style="list-style-type: none"> • Number of Hydrant per floor | Required | Provided | MR |
| | <ul style="list-style-type: none"> • Hose box. | Required | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> • Hose box. | -NA- | N/A | N/A |
| 13 | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> • Ground Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of main pump. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Head of main pump. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Number of main pumps. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Jockey Pump output. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Jockey Pump head. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Standby Pump output. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Standby Pump head. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Pump House Access | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> • Terrace Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of pump. | 450 LPM | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Head of pump. | 40m | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Power supply. | Required | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Auto starting of pump. | Required | Provided | MR |
| 14 | Captive water storage for Fire Fighting. | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Draw-off connection. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Fire Service Inlet. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Access to tank. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> • Overhead tank capacity. | 20,000 Ltr | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of lift shaft. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> • Pressurization of lift lobby. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> • Communication in lift car. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> • Fireman's switch. | -NA- | N/A | N/A |
| | <ul style="list-style-type: none"> • Lift signage. | -NA- | N/A | N/A |
| 17 | Standby Power Supply | -NA- | N/A | N/A |
| 18 | Refuge Area | | | |
| | <ul style="list-style-type: none"> • Total area | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Location | -NA- | -NA- | -NA- |

2

11/23

| | | | | |
|----|---|------|-----|-----|
| 19 | Fire Control Room. | | | |
| | • Detector System Panel. | -NA- | N/A | N/A |
| | • Flow Switch Panel. | -NA- | N/A | N/A |
| | • PA system Panel. | -NA- | N/A | N/A |
| | • Battery backup | -NA- | N/A | N/A |
| | • Building floor plan | -NA- | N/A | N/A |
| 20 | Special Fire Protection System for the Protection of special Risk, if any : | -NA- | N/A | N/A |

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department wide letter of even no 498 dated 08/11/2024.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Design: ADO (BCP)

DO (south)

~~Director~~ 9/11/24

~~CPD (S)~~

~~Director~~ 9/11/2024

~~Director~~ 14/11/24

~~ADO (BCP)~~

As approved, F-1. letter is put up for your signature @ 11/12/2024

~~Director~~ 11/12/24

Uploaded 13/12/24