



**FIRE SAFETY CERTIFICATE**

Certified that the **MCD Primary School (Co-Ed)** located at **Jwala Nagar, Delhi - 110032**, building comprised of **Ground plus two upper floors** owned/occupied by **MCD Primary School (Co-Ed)** was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/1000 dated 10/12/2021. The School building was re-inspected by the officer concerned of this department on 10/12/2024 in presence of Mrs. Maya Rani (In-Charge) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **"Educational Building" (Group - B)** with effect from 18/12/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 18/12/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

OK @ DELHI FIRE SERVICE

**Copy to: -**

1. The Dy. Director of Education, Municipal Corporation of Delhi, 419 Udyog Sadan, Patparganj Industrial Area, Delhi – 110092.
2. The Principal, MCD Primary School (Co-Ed) located at Jwala Nagar, Delhi – 110032.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



**INSPECTION REPORT**

1	Name & address of the building	MCD Primary School (Co-Ed) located at Jwala Nagar, Delhi - 110032.		
2	Building is comprised of	Ground plus two upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/1000 dated 10/12/2021		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	10/12/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (Laxmi Nagar)		
9	Name of the designation of officer from the building side	Mrs. Maya Rani (In-Charge)		
10	Year of construction	2012		
11	Applicant's letter no.	Email Dated 28/11/2024		
S. No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to Building:</b>			
	A Road width	6.0 meters.	8.0 meters.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	01 no.	02 nos.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 meters.	1.40 meter & 1.50 meters	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	1.50 meters	1.71 meters.	MR
	F Door size	1.0 meter.	1.0 meter.	MR
3.	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4.	<b>Smoke Management System:</b>			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

5. Fire Extinguisher:					
	A	Total numbers	06 nos.	30 nos.	MR
	B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:					
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:					
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:					
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump each block	450 LPM	450 LPM	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR



N/15

14	<b>Captive Water Storage for Fire Fighting:</b>			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 liters	10,000 liters
15	<b>Exit Signage:</b>		Required	Provided
16	<b>Provision of Lifts:</b>			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	<b>Standby Power Supply:</b>			
18	<b>Refuge Area:</b>			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	<b>Fire Control Room:</b>			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/1000 dated 10/12/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed. No file is pending with me before disposal of this case.

Signature of the Inspecting Officer  
 Name Yashwant Singh Meena  
 Designation ADO/Laxmi Nagar

Approved  
 12/12/2024

NDZ  
 13/12/24

13/12/2024

Director  
 13/12/24

P.T.O