

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 744

Dated: 20/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Metro Station, DMRC** located at Metro station, Sector – 13, Dwarka. New Delhi, comprised of Ground, + 01 Upper Floor was issued FSC vide letter no. F6/DFS/MS/SZ/2021/535 dated 28-10-2021. The premises was re inspected by the officer concerned of this department on 12/12/2024 in the presence of Sh. Sanyam Jain (Manager Fire) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D – 7 (Except PD Area) with effect from 20/12/2024.. for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..20/12/2024... at New Delhi by.

(Ajul Garg)  
Director.

Delhi Fire Service

Copy to:

1. Sh. Rajesh Aggarwal GM/E&M, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi – 110001.
2. Sh. Sanyam Jain, Metro station, Sector – 13, Dwarka. New Delhi.

**Condition for the validity of fire safety certificate:-**

1. **The FSC is valid for metro station (except PD Area).**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The basement if any shall be used as per building bye laws 1983.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/14

**INSPECTION REPORT**

1. Name & address of the building : Metro station, Sector - 13, Dwarka. New Delhi.
2. Type of Occupancy : Assembly (D - 7) (G+1)
3. Type of Case : Renewal (Ground + One Upper floor)
4. Details of previous NOC : F6/DFS/MS/SZ/2021/535 dated 28-10-2021
5. Fire Safety directives L. No. : F.5/DFS/MS/BP/2006/569 Dated 08/03/2006
6. Date of inspection : 12-12-2024
7. Name of the Inspecting Officer : Udai Vir Singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Sanyam Jain (Manager Fire)
9. Year of Construction : 2006
10. Applicant's letter No.: DMRC/O&M/Fire/NOC/L-3/2024/11/03 dated 14/11/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building		20 mtr	MR
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Required 4.5 mtr NA	Directly accessible from road NA	MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	04 (concourse to platform)	Provided	MR
	b. Width of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	2x2m (each platform)	Old case	MR (Being old case)
	c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required	Provided	MR
	d. No of continuous staircase to terrace <ul style="list-style-type: none"> <li>• Width Of Corridor</li> <li>• Door Size</li> </ul>	NA	NA	NA
		NA	NA	NA
		2 mtr	Old caase	MR
		1.5 m	Old case	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
		02 hrs	Provided	MR
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA	NA	NA
		NA	NA	NA

*(Handwritten signature/initials)*

M/S

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	33 Nos. CO2 & Water Required	Provided Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	04 on each platform 04 (concourse/ground level) 45 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150mm 04 at platform 04 at concourse Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	02 Nos. Required	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	All the pumps are connected with generator also		
		1800lpm	Provided	MR
		7 0m	Provided	MR
		1	Provided	MR
		180 lpm	Provided	MR
		7 0m	Provided	MR
		1800 lpm	Provided	MR
		7 0m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	10,0000ltrs Required Required Required NA	Provided Provided Provided Provided NA	MR MR MR MR NA
15	Exit Signage	Required	Provided	MR

Handwritten marks at the bottom of the page.

N/16

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Auto and manual CO2 trace tube flooding system is provided for HT/LT electrical panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/SZ/2021/535 dated 28-10-2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Signature of the Inspecting Officer  
 Name Uday Vir Singh  
 Designation ADO/DWR

~~Signature~~ 13/12/24

CFO/(S2)

~~Signature~~ 13/12/2024

Sir AT letter is put up for sig plc

~~DIRECTOR~~

13/12/24