

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
No. F.6/DFS/MS/EH/2024/SZ/412 Dated: 17/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of **M/s SIDEWORK FEZ Restaurant** located at Unit No F 01 F 02 F 03 and F 04, First Floor, Sangam Cinema, Major Som Nath Marg, Sector 9, R.K Puram, New Delhi 110022 in the building comprised of 03 tier Basement, ground plus three upper floor owned/occupied by A Unit of Malik Enterprise was issued FSC by this department vide letter no F6/DFS/MS/EH/2021/SZ/382 dated 29/12/2021. The premise was re-inspected by the officers concerned of this department on 12/12/2024 in the presence of Mr. Kapil and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy **Class- D " Assembly Building"** (Restaurant at FF only) and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on17..12./2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police (Lic/Branch), First floor, P.S. Defence Colony, New Delhi-110049 (MCD Portal ID 2024111816897 dated 18/11/2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

r/12

INSPECTION REPORT



1	Name & Address of the Building	M/s SIDEWORK FEZ Restaurant (A Unit of Malik Enterprise), located at Unit No F 01 F 02 F 03 and F 04, First Floor, Sangam Cinema, Major Som Nath Marg, Sector 9, R.K Puram, New Delhi 110022		
2	Type of Occupancy	Group-D Assembly Building. (Eating house)		
3	Building Comprised of	03 tier basement, ground plus three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2021/SZ/382 dated 29/12/2021		
6	Fire Safety Directives Letter No	F6/DFS/MS/Cinema/2023/SZ/576 dated 01/12/2023		
7	Date of Inspection	12/12/2024		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Kapil		
10	Year of construction	2009	Restt. located at First floor only	
11	Applicant letter No.	MCD Portal ID 2024111816897 dated 18/11/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL-2016 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.	F6/DFS/MS/Cinema/2023/SZ/576 dated 01/12/2023		
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required Required Required	12 mtr* Provided* Provided*	MR MR MR
2	Number, width, type & arrangement of exits.	Provided & Maintained by Mall		
	a) Number of Staircase	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Upper floors. Basement floor. 	04 No N/A	Provided* Provided*	NA N/A
	b) Width of Staircase	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Upper floors Basement floor 	1.50 mtr each N/A	Provided* Provided*	NA N/A
	c) Protection of exits	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.50 mtr each	1.6 m & 1.50 m	MR
3	Compartmentation.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	Required Required N/A N/A N/A	Provided* Provided* N/A N/A N/A	MR MR N/A N/A N/A
4	Smoke Management system.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH 12 ACPH	Provided* Exhaust Fans Provided	MR MR
5	Fire Extinguishers.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required ABC/CO ₂ ISI marked	10 Nos ABC-07 & CO ₂ -03 Provided	MR MR MR
6	First Aid Hose Reels.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	Near restt. 30m 5mm	Provided* Provided* Provided*	MR MR MR
7	Automatic fire detection & alarming system.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel 	Required Required Required	Provided* Provided* Provided*	MR MR MR

M13

	<ul style="list-style-type: none"> • Alternate source of power • Hooter's location 	Required	Provided*	MR
		Required	Provided*	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floor / Restt. Area 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> • Size of Riser/Down-comer 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Number of Hydrant per floor 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Hose box. 	Required	Provided*	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hose box. 	N/A	N/A	N/A
13	Pumping arrangements.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	2850 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Head of main pump. 	70 m	Provided*	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	02	Provided*	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	180 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	70 m	Provided*	MR
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	2850 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	70 m	Provided*	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Pump house access. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	N/A	Provided*	N/A
	<ul style="list-style-type: none"> ➤ Head of pump. 	N/A	Provided*	N/A
	<ul style="list-style-type: none"> ➤ Power supply. 	N/A	Provided*	N/A
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	N/A	Provided*	N/A
14	Captive water storage for fire fighting.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> • Underground tank capacity. 	2,00,000 ltrs	Provided*	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Overhead tank capacity. 	20,000 ltrs	Provided*	MR
		Required	Provided*	MR
15	Exit Signage.	Provided & Maintained by Mall		
16	Provision of Lifts.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> • Pressurization of lift shaft. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Pressurization of lift lobby. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Communication in lift car. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Fireman's switch. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Lift signage. 	Required	Provided*	MR
17	Standby Power Supply	Required	Provided*	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location 	N/A	N/A	N/A
19	Fire Control Room.	Provided & Maintained by Mall		
	<ul style="list-style-type: none"> • Detector system panel. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Flow switch panel. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • PA system panel. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Battery backup. 	Required	Provided*	MR
	<ul style="list-style-type: none"> • Building floor plan. 	Required	Provided*	MR
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

r/14



The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2021/SZ/382 dated 29/12/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature
12/12/2024

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (South)

Signature
13/12/2024

CTO (RCS)

Signature
13/12/2024

Director

Signature

Signature

As approved, F.T. letter is put up for your signature @

Signature
16/12/2024

Director
Signature
17/12/24

Uploaded
18/12/24
Signature