

C/24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2024/ 1213

Dated: 23/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Arya Kumar Convent School** at Durga Vihar, Phase-1, Roshanpura, Najafgarh, New Delhi-110043, comprised of ground plus two upper floors, owned/occupied by Arya Kumar Convent School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/school/SZ/2021/1080 dated 27.12.2021. The school building was re-inspected by the officer concerned of this department on dated 13.12.2024 in the presence of Mr. Rakesh Kumar (Managing Director) and found that school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**ground plus two upper floors only**) is fit for occupancy class "**Educational Building**" w.e.f. 23/12/24 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 23/12/2024 at New Delhi.

  
(Atul Garg)

Director

Delhi Fire Service

Copy to: -

1. The Principal, Arya Kumar Convent School at Durga Vihar, Phase-1, Roshanpura, Najafgarh, New Delhi-110043.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

M17

**INSPECTION REPORT**

1. Name & address of the build : Arya Kumar Convent School, DurgaVihar, Phase-1, Roshanpura, Najafgarh New Delhi-110043.
2. Building is comprised of : Ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/SZ/2021/1080 dated 27.12.2021.
6. Fire Safety direction letter No : N.A
7. Date of Inspection : 13.12.2024
8. Name of the Inspecting Officers : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Mr. Rakesh Kumar (Managing Director)
10. Year of Construction : 2005
11. Applicant's letter No : AKCS-679/2024-25 dated 12.11.2024

Sr. No.	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	6 m.	Provided	MR
	Gate width	4.5 m.	Direct accessible from road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	a. Number of Staircases			
	Upper Floor	02 nos.	02nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 & .75 m	1.5 & 1.35 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	One	N.A.
	g. Width of Corridor	1.5 m	3.0 m	MR
	h. Door Size	1.0 m	1.10 m	MR
3	<b>Compartmentation.</b>			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	<b>Smoke Management System.</b>			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural Ventilation Provided	MR

5.	<b>Fire Extinguisher</b>			
	Total numbers	08 Nos.	08Nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	One	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	<b>Internal Hydrants</b>			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	<b>Yard Hydrants.</b>			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	<b>Pumping Arrangements.</b>			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

M 19

16	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	<b>Standby power supply</b>	N.A.	N.A.	N.A.
18	<b>Refuge Area.</b>			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	<b>Fire Control Room</b>			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/school/SZ/2021/1080 dated 27.12.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*R. K. Yadav*  
12/12/2024

Signature of the Inspecting Officer  
Name- R. K. Yadav  
Designation- ADO (JKP)

D.O. (South West)  
*[Signature]* 18/12/24

CFO (S2)  
*[Signature]* 18/12/2024

~~Director MS~~  
*[Signature]* 19/12/24

*ADP/SKD*