

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2024/EH/418

Dated: 20/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Big tree café Dwarka Located at Plot No. 15, 3<sup>rd</sup> floor, service centre, Sector – 20, Dwarka, New Delhi – 110075 (Restaurant is running at 3<sup>rd</sup> Floor in a building comprised of G+3UFs owned/ occupied Big tree café have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 11/12/2024 in the presence of Sh. Rahul (Partner) and found that the said building that the premises is fit for occupancy class " Assembly" Group D (3<sup>rd</sup> floor) with effect from 20/12/2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/12/2024 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service  
12/12/24

Copy to:

1. The Joint Commissioner Police, Licensing, 1<sup>st</sup> Floor, PS, Defence Colony, N Delhi.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement if any shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

11/5

**INSPECTION REPORT**

1. Name & address of the building: Big tree café Dwarka Located at Plot No. 15, 3<sup>rd</sup> floor, service centre, Sector – 20, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Assembly D (Restaurant)
3. Type of Case : New ((Restaurant is running at 3<sup>rd</sup> Floor in a building comprised of G+3UFs.
4. Details of previous NOC: Nil
5. Fire Safety directives Letter No. : **UBBL/NBC**
6. Date of inspection : 11/12/2024
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer  
from the building side : Mr. Rahul (Partner )
9. Year of Construction : Not Known
10. Applicant's letter No. : 2024112517274 dated 02/12/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	09 m	Provided	MR
	• Gate width	.....	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	02	03 provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr each	2x150cm & 1x120cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X 1.5 mtr	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

10/12

N/6

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ac per hour	provided	MR
5.	Fire Extinguishers			
	• Total numbers	4 nos. CO2 or	05 Nos.	MR
	• Types	ABC	ABC	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• 2 <sup>nd</sup> Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	70 mtr	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	70 mtr	Provided	MR
	➤ Standby Pump out put	2280 lpm	Provided	MR
	➤ Standby Pump Head	70 mtr	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR



14	Captive water Storage for fire fighting			
	• Under ground tank capacity	1,00,000 ltr	Provided (Dimension provided)	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	DG Set	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. If approved, the FSC may be issued.

1. Big tree café Dwarka Located at Plot No. 15, 3<sup>rd</sup> floor, service centre, Sector - 20, Dwarka, New Delhi - 110075
2. The total area of the restaurant is 204 M<sup>2</sup> (As per letter/ plan submitted by the applicant)
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 113 (204/1.8=113) for whole restaurant.
4. The total seating capacity comes out to be 113.

Note:- Photographs and dimension (Capacity of fire doors) are placed (C/15 to C/19)

Sign of Inspecting Officer  
Name: Sh. Vedpal  
Designation: DO/SW

Sign of Inspecting Officer  
Name: Udai vir Singh  
Designation: ADO/DWK

CFO (S2)  
13/11/2011

FTA  
ADO/DWK