

C32

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F-6/DFS/MS/SZ/2024/EH/416

Dated: 20/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Duty free (A unit of Dream Bar Pvt Ltd) Located at Shop No. R-03, 5<sup>th</sup> Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110078 in a building comprised of four tier Basement + Ground + 05 Upper Floors was issued FSC by this department vide letter F6/DFS/MS/SZ/2021/359 Dated 09/12/2021(Issued to Duty free) & F6/DFS/MS/SZ/2022/62 dated 09/12/2022 (Issued to mall). The premises was re - inspected by the officer concerned of this department on 11/12/2024 in the presence of Mr. Taj Singh (Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class "Assembly" Group D (Shop No. R-03, 5<sup>th</sup> Floor) with effect from 20/12/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...20/12/2024... at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service  
11/12/24

Copy to:

1. The Joint Commissioner Police, Licensing, 1<sup>st</sup> Floor, PS. Defence Colony, New Delhi.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

**INSPECTION REPORT**

N-5

1. Name & address of the building: **M/S Duty free (A unit of Dream Bar Pvt Ltd) Located at Shop No. R-03, 5<sup>th</sup> Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110078.**
2. Type of Occupancy : **Class-D (Assembly)( At Fifth Floor in the Mall)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/SZ/2021/359 Dated 09/12/2021(Issued to Duty free) & F6/DFS/MS/SZ/2022/62 dated 09/12/2022 (Issued to mall)**
5. Fire Safety directives Letter No. : **F6/DFS/MS/BP/2016/326 Dated 16/12/2016(issued to mall)**
6. Date of inspection : **11/12/2024**
7. Name of the Inspecting Officer ; **DO/SW & ADO (DWK)**
8. Name and designation of Officer  
 from the building side : **Mr. Taj Singh (Manager)**
9. Year of Construction : **2019**
10. Applicant's letter No. : **2024120217527 Dated-02/12/2024**

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1	<b>Access of building</b>			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2	<b>Number, width, Type &amp; Arrangements of exits( Common With Mall)</b>			
	a. Number of staircases			
	• Upper floors	2	03 Provided (by Mall)	MR
	• Basements	NA	12 Provided by Mall	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided by Mall	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	Provided	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2x 1.5 M	<b>Provided ( including door frame)</b>	<b>MR</b>

N-6

3.	<b>Compartmentation( Common With Mall)</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	Provided by Mall	NA
		NA	Provided by Mall	NA
		NA	Provided by Mall	NA
		NA	Provided by Mall	NA
		NA	Provided by Mall	NA
4.	<b>Smoke managements System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA	NA	NA
		12 a/c per hour	Provided by Mall	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	03 nos. each type,ABC, CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	<b>First – Aid Hose Reel</b>	<b>Common with mall</b>		
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	Required	Provided by Mall	MR
		36 m	Provided by Mall	MR
		5 mm	Provided by Mall	MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Smoke/ Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided by Mall	MR
10.	<b>Automatic Sprinkler System (Common with mall)</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA	Provided	NA
		Required	Provided	MR
		Required	Provided	MR
11.	<b>Internal Hydrants: (common with the mall)</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	150 mm	Provided by Mall	MR
		1	3 Provided by Mall	MR
		Required	Provided by Mall	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	Provided by Mall	NA
		NA	Provided by Mall	NA

13.	<b>Pumping Arrangements: Common with Mall</b>																																								
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li>   <li>➤ Jockey pump head</li>   <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li>   <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	<table border="1"> <tr> <td>2280 lpm</td> <td>2850 LPM Provided By Mall</td> <td>MR</td> </tr> <tr> <td>120 mtr</td> <td>120 mtr Provided By Mall</td> <td>MR</td> </tr> <tr> <td>01</td> <td>2 electric Provided By Mall</td> <td>MR</td> </tr> <tr> <td>180 lpm</td> <td>180 LPM 2 Nos+Water Curtain Pump 2280 LPM Provided By Mall</td> <td>MR</td> </tr> <tr> <td>120 mtr</td> <td>120 mtr+Water Curtain 60 mtrs Provided By Mall</td> <td>MR</td> </tr> <tr> <td>2280 lpm</td> <td>2850 LPM Provided By Mall</td> <td>MR</td> </tr> <tr> <td>120 mtr</td> <td>120mtr Provided By Mall</td> <td>MR</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>MR</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>MR</td> </tr> <tr> <td>900lpm</td> <td>Provided By Mall</td> <td>MR</td> </tr> <tr> <td>40 m</td> <td>Provided By Mall</td> <td>MR</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>MR</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>MR</td> </tr> </table>	2280 lpm	2850 LPM Provided By Mall	MR	120 mtr	120 mtr Provided By Mall	MR	01	2 electric Provided By Mall	MR	180 lpm	180 LPM 2 Nos+Water Curtain Pump 2280 LPM Provided By Mall	MR	120 mtr	120 mtr+Water Curtain 60 mtrs Provided By Mall	MR	2280 lpm	2850 LPM Provided By Mall	MR	120 mtr	120mtr Provided By Mall	MR	Required	Provided By Mall	MR	Required	Provided By Mall	MR	900lpm	Provided By Mall	MR	40 m	Provided By Mall	MR	Required	Provided By Mall	MR	Required	Provided By Mall	MR
2280 lpm	2850 LPM Provided By Mall	MR																																							
120 mtr	120 mtr Provided By Mall	MR																																							
01	2 electric Provided By Mall	MR																																							
180 lpm	180 LPM 2 Nos+Water Curtain Pump 2280 LPM Provided By Mall	MR																																							
120 mtr	120 mtr+Water Curtain 60 mtrs Provided By Mall	MR																																							
2280 lpm	2850 LPM Provided By Mall	MR																																							
120 mtr	120mtr Provided By Mall	MR																																							
Required	Provided By Mall	MR																																							
Required	Provided By Mall	MR																																							
900lpm	Provided By Mall	MR																																							
40 m	Provided By Mall	MR																																							
Required	Provided By Mall	MR																																							
Required	Provided By Mall	MR																																							
14.	<b>Captive water Storage for fire lighting: Common with Mall</b>																																								
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	<table border="1"> <tr> <td>1,50,000</td> <td>400000 l ( By Mall)</td> <td>NA</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>10, 000 litres</td> <td>Provided By Mall</td> <td>MR</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>MR</td> </tr> </table>	1,50,000	400000 l ( By Mall)	NA	Required	Provided By Mall	NA	Required	Provided By Mall	NA	Required	Provided By Mall	NA	10, 000 litres	Provided By Mall	MR	Required	Provided By Mall	MR																					
1,50,000	400000 l ( By Mall)	NA																																							
Required	Provided By Mall	NA																																							
Required	Provided By Mall	NA																																							
Required	Provided By Mall	NA																																							
10, 000 litres	Provided By Mall	MR																																							
Required	Provided By Mall	MR																																							
15.	<b>Exit Signage</b>																																								
16.	<b>Provision of Lifts Common with Mall</b>																																								
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	<table border="1"> <tr> <td>NA</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>Provided By Mall</td> <td>NA</td> </tr> <tr> <td>Required</td> <td>Provided By Mall</td> <td>MR</td> </tr> </table>	NA	Provided By Mall	NA	NA	Provided By Mall	NA	NA	Provided By Mall	NA	NA	Provided By Mall	NA	NA	Provided By Mall	NA	Required	Provided By Mall	MR																					
NA	Provided By Mall	NA																																							
NA	Provided By Mall	NA																																							
NA	Provided By Mall	NA																																							
NA	Provided By Mall	NA																																							
NA	Provided By Mall	NA																																							
Required	Provided By Mall	MR																																							
17.	<b>Standby power supply</b>																																								
18.	<b>Refuge Area</b>																																								
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	<table border="1"> <tr> <td>NA</td> <td>Provided</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>Provided</td> <td>NA</td> </tr> </table>	NA	Provided	NA	NA	Provided	NA																																	
NA	Provided	NA																																							
NA	Provided	NA																																							

Handwritten marks at the bottom of the page, including a large 'G' and a signature.