



c/s 47



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2024/ 422

Dated: 23/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. F One Café Located at F-1, Second & Third floor, Kalka Ji, Delhi-110019, running at Second & Third floor, in a building comprised of Basement + Ground + 03 Upper Floor. The building/premises was inspected by the officer concerned of this department on 17/12/2024 in the presence of Sh. Lala Ram Verma and found that the said premises/building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) with effect from 23/12/2024 and valid upto 31.03.2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on 23/12/2024 at New Delhi by.

  
(Atul Garg)  
Director

Copy to: -

1. The owner/occupier, M/s. F One Café Located at F-1, Second & Third floor, Kalka Ji, Delhi-110019.
2. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. ( [adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in).)
3. The Dy. Health Officer, MCD, Office of Dy Health Officer, South Zone, Green Park, New Delhi-110016 ( [mcd-ithelpdesk@mcd.nic.in](mailto:mcd-ithelpdesk@mcd.nic.in)).

## INSPECTION REPORT

1.	Name & address of the building	M/s. F One Café Located at F-1, Second & Third floor, Kalka Ji, Delhi-110019.
2.	Type of Occupancy	Assembly (Group-D)
3.	Type of Case	New case
4.	Details of previous NOC	Nil
5.	Fire Safety directives letter No	Nil
6.	Date of inspection	17/12/2024
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Lala Ram Verma
9.	Year of Construction	2000
10.	Applicant's letter No.	MHA Portal ID No. - 202412107846 dated 10/12/2024

The said building is comprised of Basement, Ground and three upper floors (Restaurant running at Second & Third floor Only).

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 m	15mts Provided	MR
	• Gate width	4.5 m	Direct Accessible	MR
	• Width of internal road	NA	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	03 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	1.5 mts each	Provided	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5 mts	Provided	MR
	g. Door Size	2X1.5mts	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	06 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR

✓

PM2

	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30m 5mm	Provided Provided	MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required Required NA Required Required	Provided Provided NA Provided Provided	MR MR NA MR MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 01 01	Provided Provided Provided	MR MR MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	2280 LPM each 60M 01 180 LPM 60M 2280 LPM 60M Required Required 450 LPM 40M Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	1,00,000 ltrs Required Required Required 10,000 ltrs	Provided Provided Provided Provided Provided	MR MR MR MR MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	NA NA	NA NA	NA NA

82


Provision of Lifts.				
16	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
Refuge Area.				
18	<ul style="list-style-type: none"> <li>&gt; Total Area</li> <li>&gt; Location</li> </ul>	NA	NA	NA
		NA	NA	NA
Fire Control Room				
19	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. Earlier all the shortcomings issued by this department have been complied by the restaurant management.

Keeping in view the substantial compliance of the minimum standards on fire prevention & fire safety requirement under the rules and it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

ADO/MNO  
12/2024

DO (S)

  
Signature of the Inspecting Officer  
Sarabjeet Singh ADO (MN)



CF (MNO)  
20/12/2024  
Director

FT 75

ADO/MNO

Sir, F.T is put up for your  
Kind personal & Sj. pls.

  
20/12/2024

Director



(2) (2) (2)