



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 1219

Dated: 23/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Sarvodaya (Co-Ed) Vidyalaya**, Varun Marg, Defence Colony, New Delhi-110024. (School ID No.1924014), comprised of Ground + 03 Upper Floors (SPS Shed), was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2022/SZ/12 dated 05/01/2022. The premise was re-inspected by the officer concerned of this department on dated 12/12/2024 in the presence of Sh. Vinod Kumar (Principal) and observed that the said premises have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of DFS Rules, 2010 and that the premises/building is fit for occupancy class "**Educational**" (Group-B) as above, with effect from 23/12/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/12/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Principal, Govt. Sarvodaya (Co-Ed) Vidyalaya, Varun Marg, Defence Colony, New Delhi-110024. (School ID No.1924014).
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1.	Name & address of the building	Govt. Sarvodaya (Co-Ed) Vidyalaya, Varun Marg, Defence Colony, New Delhi-110024. (School ID No.1924014)		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	Ground + 03 Upper Floors (SPS Shed)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/2022/SZ/12 dt.05/01/2022		
6.	Fire Safety directives Letter No.	NBC Part- IV		
7.	Date of inspection	12/12/2024		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Mr. Vinod Kumar (Principal)		
10.	Year of Construction	2020		
11.	Applicant's letter No.	Outdoor diary No. 9897 dated 03/12/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6m 4.5m NA	6m 4.5m NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	02 Nos NA	03 Nos NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	1.5m NA	1.80m x 3 Nos NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	01	03 Nos	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1m	1.10m x 2	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	10 Nos ABC/CO <sub>2</sub> ISI Marked	20 Nos ABC & CO <sub>2</sub> Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	02 Nos 30m 5mm	04 Nos Provided Provided	MR MR MR



7.	Automatic fire detection and alarming system	NA	NA	NA
	<ul style="list-style-type: none"> <li>Type of detector</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	Internal Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
12.	Yard Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual stopping</li> <li>Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	450 LPM 40m Required	450 LPM x 2 40m Provided	MR MR MR MR
14.	Captive Water Storage for firefighting	NA	NA	NA
	<ul style="list-style-type: none"> <li>Underground tank capacity                             <ul style="list-style-type: none"> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA NA NA NA 10000 Ltr	NA NA NA NA Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA NA	NA NA	NA NA

19.	Fire Control Room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/2022/SZ/12 dated 05/01/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Santosh Kumar*  
16.12.24

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD) *[Signature]*

CO (RCS)  
*[Signature]*  
18/12/2024  
Director  
*[Signature]*  
18/12/24  
ADY/SJ

Sir,  
F.T letter is put up for your sig. pl

Director  
*[Signature]*  
21/12/24  
2

*Santosh Kumar*  
20/12/24