

c/27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/School/2024/SZ/ 1215

Dated: 23/12/2024

FIRE SAFETY CERTIFICATE

Certified that the **Maharishi Dayanand Public School**, J-3/206-207, Rajouri Garden, New Delhi-110027, comprised of ground plus two upper floors, owned/occupied by Maharishi Dayanand Public School was issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2021/SZ/913 dated 01.11.2021. The school building was re-inspected by the officer concerned of this department on dated 12.12.2024 in the presence of Sh. Deepak (Caretaker) and found that school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**ground plus two upper floors only**) is fit for occupancy class "**Educational Building**" w.e.f. 23/12/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.
Issued on 23/12/2024 at New Delhi.


(**And Gaur**)
Director
Delhi Fire Service


Copy to: -

1. The Principal, Maharishi Dayanand Public School, J-3/206-207, Rajouri Garden, New Delhi-110027.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Maharishi Dayanand Public School, J-3/206-207, Rajouri Garden, New Delhi-27.
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2021/SZ/913 dated 01.11.2021
6. Fire Safety Circular No. : NBC Part-IV
7. Date of Inspection : 12.12.2024
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of
Officer from the building side : Sh. Deepak (Caretaker)
10. Year of Construction : Before 1985
11. Applicant's letter No : 8/EDU/MDPS/Fire Dated 15.10.2024

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	06 M	MR
	• Gate width	N/A	04 M	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	03 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M & less than	2 no. of .95 M 1.20 m (FF To SF)	MR, old case
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2 Nos	2 Nos	MR
	g. Width of Corridor	1.5 M	1.12 M	MR
	h. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 Nos.	13 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 Nos	Provided	MR
	• Length of hose reel hose	30M	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

N/12

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA			
9	Public address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			MR
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000Ltrs	Provided	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
		N/A	N/A	N/A

N/B

18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2021/SZ/913 dated 01.11.2021, renewal under rule, 37 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav
 Signature of the Inspecting Officer
 Name: R. K. Yadav
 Designation: ADO(JKP)

D.O (South West)

[Handwritten signature]
 17/12/2024
 CFO (SZ)
 17/12/2024
 Director
 17/12/2024
 ADO/JKP

FT letter is put up for sign, please

R. K. Yadav
 20/12/2024