



No. F6/DFS/MS/School/NDZ/2024/1223

Dated: 24/12/2024

FIRE SAFETY CERTIFICATE

Certified that the MCD Primary School, located at Mayur Vihar, Phase-1, Pocket – 1, Delhi - 110091 building comprised ground plus two upper floors owned/occupied by MCD Primary School was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/NDZ/2021/926 dated 08/11/2021. The School building was re-inspected by the officer concerned of this department on 11.12.2024 in presence of Mrs. Vineeta Bhatia (Principal) and found that all the said school have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the school is fit for occupancy class Group- B “Educational Building” with effect from 24/12/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 24/12/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD. 419, Patparganj Industrial Area, Delhi-110092
2. The Principal, MCD Primary School, located at Mayur Vihar, Phase-1, Pocket – 1, Delhi - 110091.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	MCD Primary School, located at Mayur Vihar, Phase-1, Pocket – 1, Delhi - 110091.		
2	Building is comprised of	Ground plus two upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/926 dated 08/11/2021		
6	Fire safety directives letter no.	N/A		
7	Date of inspection	11.12.2024.		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs.Vineeta Bhatia (Principal)		
10	Year of construction	1984 & 2014		
11	Applicant's letter no.	Email dated 03/12/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement As per NBC	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	12 mtrs.	MR
B	Gate width	4.5 mtrs	05 mtrs	MR
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	03 no.	03 nos. ✓	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 mtrs	03 mtrs of 1.5 mtrs ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 nos.	02 nos. ✓	MR
E	Width of corridor	1.5 mtrs.	1.5 mtrs. ✓	MR
F	Door size	1.0 mtrs.	1.0 mtrs. ✓	MR
3	Compartmentation:			
A	Fire check door	NA	NA ✓	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

N/18


5.	Fire Extinguisher:				
	A	Total numbers	06 nos.	06 nos. /	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no	01 no /	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:				
			N/A	N/A	N/A
9	Public Address System:				
			N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM /	MR
	B	Head of the pump	40 m	40 m /	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR





14	Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A	
B	Draw-off connection	N/A	N/A	N/A	
C	Fire service inlet	N/A	N/A	N/A	
D	Access to tank	N/A	N/A	N/A	
E	Overhead tank capacity	10,000 liters	10,000 liters	MR	
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A	
B	Pressurization of lift lobby	N/A	N/A	N/A	
C	Communication in lift car	N/A	N/A	N/A	
D	Firemen's grounding switch	N/A	N/A	N/A	
E	Lift signage	N/A	N/A	N/A	
17	Standby Power Supply:		N/A	N/A	N/A
18	Refuge Area:				
A	Total area	N/A	N/A	N/A	
B	Location	N/A	N/A	N/A	
19	Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A	
B	Flow switch panel	N/A	N/A	N/A	
C	PA system panel	N/A	N/A	N/A	
D	Battery backup	N/A	N/A	N/A	
E	Building floor plans	N/A	N/A	N/A	
20	Special Fire Protection systems for protection of special Risks, if any:			N/A	

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/NDZ/2021/926 dated 08/11/2021, renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

No file is pending with me before disposal of this case.


 17/12/2024
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

DO/East

 17.12.2024
 by C.F.O. (NDZ) 
 C.F.O.

 18/12/2024
 Director 
 18/12/2024
