

c/29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/ 1216

Dated: 23/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Sanatan Dharam Vidya Bhavan**, at R-4, Raghunath Mandir, Alaknanda, Kalkaji, New Delhi 110019 comprised of Ground plus Two upper floor owned/occupied by M/s Sanatan Dharam Vidya Bhavan was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2019/SZ/104 dated 15/01/2019. The said premises was re-inspected by officer concerned of this department on 17/12/2024 in presence of Mrs. Usha Vasudevan (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 23/12/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 23/12/2024 at New Delhi by

  
**ATUL GARG  
DIRECTOR  
DELHI FIRE SERVICE**  


Copy to: -

1. M/s Sanatan Dharam Vidya Bhavan, at R-4, Raghunath Mandir, Alaknanda, Kalkaji, New Delhi 110019
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	Sanatan Dharam Vidya Bhavan, at R-4, Raghunath Mandir, Alaknanda, Kalkaji, New Delhi 110019		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus Two upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/104 dated 15/01/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	17-12-2024		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Usha Vasudevan (Principal)		
10	Year of construction	2001		
11	Applicant letter No.	Email Dated 09/12/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 m	09 mtr	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 nos	02 nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m /0.75m	1.20m & 1.07m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	02 no Provided	MR
	e) Width of corridor	1.50 mtr	Provided	MR
	f) Door size	01 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	15 Nos	15 Nos	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No each	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> <li>• Number of Hydrant per floor</li> <li>• Hose box.</li> </ul>	100mm	Provided	MR
		01 no	Provided	MR
		01 no	Provided	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> <li>➤ Discharge of main pump.</li> <li>➤ Head of main pump.</li> <li>➤ Number of main pumps.</li> <li>➤ Jockey Pump output.</li> <li>➤ Jockey Pump head.</li> <li>➤ Standby Pump output.</li> <li>➤ Standby Pump head.</li> <li>➤ Auto Starting/Manual Stopping.</li> <li>➤ Pump house access.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> <li>➤ Discharge of pump.</li> <li>➤ Head of pump.</li> <li>➤ Power supply.</li> <li>➤ Auto starting of pump.</li> </ul>	450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> <li>• Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 ltr	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>		-NA-	
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-
<p>The fire protection system provided in the building were randomly checked and found functional at the time of inspection.</p> <p>Further, the management has complied all the observation / Shortcoming already issued &amp; communicated by this department vide letter of even no 516 dated 09/08/2024.</p> <p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2019/SZ/104 dated 15/01/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
<p><i>[Signature]</i> 18/11/24</p> <p>Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)</p>				

DO (SD) *[Signature]* 18/11/24

CO (RCS) *[Signature]*  
18/11/2024  
Director *[Signature]*  
19/11/24

*[Signature]*  
ADY/PLP

As approved, F.T. letter is put up for your signature pl

*[Signature]*  
Director

*[Signature]*  
18/11/24

*[Signature]*