

244

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2024/School/WZ/ 1221

Dated: 24/12/2024

FIRE SAFETY CERTIFICATE

Certified that the **White Leaf Public School, Gali no.2- 3, Plot no-89, Pooth Khurd, Delhi-110039** comprised of basement + ground + 03 upper floors **but school running at Ground + 03 upper floor only** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2021/School/WZ/481 dated 14.07.2021**. The premises was re-inspected by the officer concerned of this department on **06.12.2024** in the presence of **Mr. Sunil Sharma (Principal)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 24/12/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/12/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
 2. The Principal, White Leaf Public School, Gali no.2- 3, Plot no-89, Pooth Khurd, Delhi-110039.
- Conditions for the validity of Fire Safety Certificate:**
1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
 3. The trained fire fighting staff should be available round the clock.
 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
 8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
 9. Basement is vacant not used by school management given by affidavit by school management.
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	White Leaf Public School, Gali no.2- 3, Plot no-89, Pooth Khurd, Delhi-110039.			
2. Type of Occupancy	Educational			
3. Comprised of building	Basement + Ground + 03 upper floors			
4. Type of Case	Renewal (school running at Ground + 03 upper floors only) Basement vacant given affidavit by school management			
5. Details of Previous NOC	F.6/DFS/MS/2021/School/WZ/481 dated 14.07.2021.			
6. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011 & NBC Part-IV.			
7. Date of inspection	06.12.2024.			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
9. Name and designation of officers From the building side	Mr. Sunil Sharma (Principal)			
10. Year of Construction	2006 & 2020.			
11. Applicant's letter No.	Online e-mail dated 08.10.2024.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	DOE/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	Provided	MR
	• Basements	Not used	Not used	Not used
	b. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	Not used	Not used	Not used
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	Provided	MR
	e. Width of Corridor	1.0m	Provided	MR
	f. Door Size	1.20m	Provided	MR
3.	Compartmentation			
	f) Fire check door	-NA-	-NA-	-NA-
	g) Sealing of electrical shafts	-NA-	-NA-	-NA-
	h) Fire Rating of shaft door	-NA-	-NA-	-NA-
	i) Water Curtain	-NA-	-NA-	-NA-
	j) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	c) Basements	Not used	Not used	Not used
	d) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	d) Total numbers	15nos.	Provided	MR
	e) Types	ABC/CO2	ABC/CO2	MR
	f) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	d) Total numbers on each floor	01nos.	Provided	MR
	e) Length of hose reel hose	30mm	Provided	MR

Am

N/27

Lift Signage
Standby power
Refuge Area


	f) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			
	a) Basement	Not used	Not used	Not used
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	Required	Provided	MR
	b) Number of hydrants per floor	Required	Provided	MR
	c) Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level	900lpm	Provided	MR
	➤ Discharge of pump	40m	Provided	MR
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	15,000ltr	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-

cy

	j) Lift Signage			
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.	-NA-	-NA-	-NA-
	c) Total Area			
	d) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	f) Detector System Panel	-NA-	-NA-	-NA-
	g) Flow Switch Panel	-NA-	-NA-	-NA-
	h) PA System Panel	-NA-	-NA-	-NA-
	i) Battery backup	-NA-	-NA-	-NA-
	j) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4/DOE, and removal of shortcomings issued vide letter no. 668 dated 27.09.2024, the FSC issued vide letter no. F.6/DFS/MS/2021/School/WZ/481 dated 14.07.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

D.B Mukherjee
DO (NW)

- ① Instead of having affidavits we may use 'Declaration' on plain paper or on schools printed letter.
- ② Masonry work should be sealed by means of is required and photographs of the same


 10/12/2024

AS desired The photographs of sealed basement is placed opposite for your perusal and approval please.


 16/12/2024

No. 634/2024
 Dated: 16/12/2024


 16/12/2024