

C159

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI

No: F6/DFS/MS/School/WZ/2024/ 1229

Dated: 27/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Guru Teg Bahadur 3rd century Public School located at C- Block Mansarovar Garden New Delhi – 110015, comprised of 04 blocks (A & B Blocks Ground Plus Two Upper floors each, C & D Blocks ground Plus One upper floor each) was issued FSC vide letter No. F6/DFS/MS/School/MN/2021/378 dated 03/12/2021. The premises was re-inspected by the officer concerned by this department on 19/12/2024, in the presence of Sh. Ravi Kumar and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention & fire safety requirements in accordance with Circular No. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011/NBC part-IV issued by the Directorate of education and found that the premises is fit for occupancy class “Educational” Group B with effect from 27/12/2024 for a period of three years in accordance with effect from rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 conditions mentioned below:-

Issued on 27.12.2024 at New Delhi.


Atul Garg)
Director

o/c 26/12/2024

Copy to:

1. The Principal, Guru Teg Bahadur, 3rd, Century Public School, Mansarovar Garden, New Delhi – 110015.
2. Director of Education, Old Sectt. Delhi- 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

139
INSPECTION REPORT

1. Name & address of the building	Guru Teg Bahadur 3 rd Century Public School Located at C- Block, Mansarovar Garden, New Delhi-110015.
2. Type of Occupancy	Educational
3. Type of Case	Renewal
4. Details of Previous NOC	F6/DFS/MS/School/MN/2021/378 dated 03/12/2021
5. Fire Safety Directives letter No	Nil
6. Date of Inspection	19/12/2024
7. Name of the Inspecting Officers	Sarabjeet, ADO (MN)
8. Name and designation of officers from the building side	Ravi Kumar
9. Year of Construction	1979 (As per precious inspection report dtd 25/11/2021)
10. Applicant's letter No.	Letter No. GTB/2024/152 dated 26/11/2024

The Said school is running in total four blocks (78 Class Rooms) A = G + 2 Upper Floors, B = G + 2 Upper Floors, C = G + 1 Admin Office, D = G + 1 Primary Wing, B & C blocks are connected at 1st Floor. Total Area 2.5 acre, Covered area = 4449 Squads on Stilt, Ground and three upper floors, in a building comprised of Stilt + Ground + 03 upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	4.5m Provided	MR
	• Gate width	Accessible	4.7m Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	A Block=2 B Block=2 C Block=3 D Block=1	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m	A-Block=1X180,1X130,1X150 cms (Iron Staircase) B Block=1X150,1X160 cms C Block=1X120 (Connected to BL-A at 1 st floor) D Block=1X130, 1 X 110cms (1 st floor not used for school activity)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	1	Provided	MR
	f. Width of Corridor	1.5m	Provided	MR
	g. Door Size	1m	Provided (with door frame)	MR Being old case
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos CO ₂ , ABC type ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	900 Lpm & 450 Lpm	MR
		NA	40m	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450Lpm	Provided at G.F.	MR being old case
		40m	Provided at G.F.	MR being old case
		Required	Provided at G.F.	MR being old case
		Required	Provided at G.F.	MR being old case
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	50,000ltrs	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	Provided	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2024/803 dated 04/12/2024 have been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/MN/2021/378 dated 03/12/2021 renewal under rule 35 of Delhi Fire Service Rules 2010 is recommended.

[Signature]
 Signature of the Inspecting Officer
 Name: - Sarabjeet Singh ADO (MN)

364/ADD/MN
 20/12/24

[Signature]
 20/12/24

[Signature]
 20/12/24

CFO
 on Leave

Director, DFS
[Signature]
 23/12/24

[Signature]
 Sir F-T is put up
 for you kind personal &
 signature please.

[Signature]
 26/11/24

DCFO... 366... WZ...
 Dated... 20/12/2024

364/ADD/MN
 26/12/2024

Director
[Signature]
 26/12/24