

C/17



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/School/ 1227

Dated: 27/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C. Primary School** located at **New Police Line, D- Block, Kingsway Camp, Delhi-110009** comprised of **Ground floor only** (hut type) owned/occupied by **M.C. Primary School** was granted FSC by this department vide letter no. **F6/DFS/MS/School/2021/365 Dated: 10.05.2021**. The premises was re-inspected by the officer concerned of this department on **18.12.2024** in presence of **Smt. Rekha (Teacher)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School)" with effect from 27/12/24 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 27/12/2024 at New Delhi by

(Atul/Garg)  
Director  
Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.
2. The HOS, M.C. Primary School located at New Police Line, D- Block, Kingsway Camp, Delhi-110009.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

- 1. Name & address of the building : M.C. Primary School, New Police Line, D- Block, Kingsway camp, Delhi-09.
- 2. Type of Occupancy : Educational
- 3. Type of Case : Renewal
- 4. Composition of building : Ground floors only
- 5. Details of previous NOC : F6/DFS/MS/School/2021/365 Dated: 10.05.2021
- 6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
- 7. Date of inspection : 18.12.2024
- 8. Name of the Inspecting Officers : ADO (RN)
- 9. Name and designation of officers from the building side : Smt. Rekha (Teacher)
- 10. Year of Construction : 1985
- 11. Applicant's letter No. : Online E-mail ID dated: 12..12.2024

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	4.5m	3.0m	MR (being old case)
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	<b>b. Width of staircases</b>			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	<b>c. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	01m	01m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	02nos	02nos	MR
	• Types	ABC/Co2	ABC-02	MR
	• ISI marking	ISI Marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA	NA	
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	<b>Exit Signage.</b>	N/A	N/A	N/A


NA  
NA

N/11

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2021/365 Dated: 10.05.2021.

  
 Signature of the Inspecting Officer  
 Name :-C.L. Meena  
 Designation:- ADO/RN

D.B. Mukharjee (DO/NW)  
  
 20/12/2024  
 Dy IFO (W2)

please see the FSC before issuance as the building is flat type.

  
 20/12/2024

  
 Director, DFS  
 on Leave

861-1163...  
 dated 20.12.2024