

C/39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2024/1234

Dated: 27 / 12 / 2024

FIRE SAFETY CERTIFICATE

Certified that the Building Vandana Kindergarten School owned/occupied by Krishna geetanjali foundation society (Regd.) Located at Sector – 10, Phase – 1, Dwarka, New Delhi – 110075 comprised of Basement + Stilt/ Ground + 3 Upper Floor was issued FSC vide Letter No. F.6/DFS/MS/School/2021/590 Dated 09/08/2021. The premises was inspected by the officer concerned of this department on 19-12-2024 in the presence of Sh. V.P Tondon (Director) and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 under DFS Act 2007 and that the premises is fit for occupancy class-B “Educational” with effect from 27/12/24 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/12/2024 at New Delhi by.

(A. Garg)
Director
Delhi Fire Service

Copy to:

1. The Principal Vandana Kindergarten School owned/occupied by Krishna geetanjali foundation society (Regd.) Located at Sector – 10, Phase – 1, Dwarka, New Delhi – 110075
2. The, Directorate of Education Old Secretariat Delhi – 110054.

Condition for the validity of fire safety certificate:-

- 1 The stairs/ passage shall be kept clear from any obstruction & free from lock & key, as seen during the inspection otherwise the FSC shall be null & void.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

119

INSPECTION REPORT

1. Name & address of the building: Vandana Kindergaten School run by Krishna geetanjali foundation society (Regd.) Located at Sector - 10, Phase - 1, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Basement + Stilt / Ground+ 3 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2021/590 Dated 09/08/2021
5. Fire Safety directives L.No. :F-16/Estate/CC/2011/3298-3398, dated 01/03/11
6. Date of inspection : 19-12-2024
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. V.P Tondon (Director)
9. Year of Construction : 2011-2012
10. Applicant's letter No. : VKGS/2024/251, dated - 14/10/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR (being old case)
	• Gate width	4.5 mtr	Provided	MR (being old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr & 0.75 m	1.51 & 0.90 mtr	MR (being old case)
	• Basements	1.5 mtr & 0.75 mtr	1.60 & 1.23 mtr (Including railing)	MR (being old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01 Nos	MR
	e. Width Of Corridor	1.5m	1.50 mtr to 2.35 mtr	MR
	f. Door Size	01 mtr	1.05 mtr to 1.10 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA


4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust fans provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	18 nos.	Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	NA	MR
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	30 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR




14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	NA	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	15000 ltrs	15000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter F.6/DFS/MS/School/2021/590 Dated 09/08/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Note :- Understudy is placed at C/37 & C/38.


 Signature of the Inspecting Officer
 Name Sh. Udai Vir Singh
 Designation ADO/DWK


 CPO / 
 Director / 
 27/11/21