



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Hospital/2024/SZ/ 758

Dated: 31/12/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Gynae Block** located at Safdarjung Hospital Complex, Ring Road, New Delhi-110029, comprised of Basement (very small lying vacant and locked), Ground plus three upper floors, owned/occupied by Ministry of Health, Govt. of India, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Hospital/2021/SZ/104 dated 09/02/2021. The said premise was re-inspected by the officer concerned of this department on 24/12/2024 in the presence of Sh. A.K. Singh (AE/Elect) & Sh. Vivek Gupta (JE/Elect) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class **“Institutional, Group-C”** (Hospital) with effect from 31/12/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 31/12/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
T.No. 011 23414000


Copy to: -

1. The Executive Engineer (Elect), SJHED Central Public Works Department, Safdarjung Hospital Complex, Ring Road, New Delhi-110029
2. The Medical Superintendent, Safdarjung Hospital, Ring Road, New Delhi-110029

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used as per the provisions of BBL.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
7. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.

INSPECTION REPORT

1	Name & Address of the Building	Gynae Block, Safdarjung Hospital Complex, Ring Road, New Delhi-110029		
2	Type of Occupancy	Institutional Building "C" (Hospital)		
3	Building Comprised of	Basement, Ground plus three upper floors. (Two blocks interconnected at ground and 2 nd floor & Basement is very small & lying vacant and locked)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Hospital/2021/SZ/104 dated 09/02/2021		
6	Fire Safety Directives Letter No	F.6/MS/DFS/88/1655 dated 10/11/1988 & F.6/MS/DFS/85/Hospital/828 dated 23/09/1985		
7	Date of Inspection	24/12/2024		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. A.K. Singh (AE/Elect) and Sh. Vivek Gupta (JE/Elect)		
10	Year of construction	1975		
11	Applicant letter No.	Email dated 23/12/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6m within Hospital Complex	Provided	MR
	• Gate width		N/A	N/A
	• Width of internal road		N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	➤ Upper floors	4 Nos	Provided	MR
	➤ Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	➤ Upper floors	Required	1.5m, 1.5m, 1.15m & 1.15m	MR (old case)
	➤ Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	2 nos.	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	ISI marked	40 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	04 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Heat & Smoke	Provided	MR
		Ground Floor	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser /Down-comer Number of Hydrant per floor Hose box. 	150 mm	Provided	MR
		04 Nos	Provided	MR
		04 Nos	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box. 	04 Nos	Provided	MR
		04 Nos	Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Common Fire Pumps for Gynae/Surgical/Ortho Blks		
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump House Access 	2850 LPM	Provided	MR
		90m	Provided	MR
		One	Provided	MR
		220 LPM	Provided	MR
		90m	Provided	MR
		2850 LPM	Provided	MR
		90m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	2,00,000 Ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19.	Fire Control Room.			
	• Detector system panel.	Required	Provided	MR
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	N/A	N/A	N/A
20.	Special fire protection system for protection of special risk, if any.	Provided CO ₂ flooding system in electric panel & ABC, CO ₂ fire extinguishers near HT/LT & Transformer		MR

The fire protection system provided in the building/premises were checked, tested at random and found functional at the time of inspection. The shortcomings communicated vide letter No. F6/DFS/MS/Hospital/SZ/2024/99 dated 05/03/2024 found complied.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/Hospital/2021/SZ/104 dated 09/02/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Suman
26/12/24
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)
[Signature]
26/12/24

cto (KCS)
[Signature]
27/12/2024

Director
[Signature]
29/12/24
ADYSI

Sir,
F.T letter is pending for your sig. pr

Director
[Signature]
31/12/24

Suman
30.12.24