

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2024/ 1239

Dated: 30/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Sr. Sec. School, Rajouri Garden, Extn. New delhi-110027. (School ID- 1515018), is running in two blocks, (Block-I ground & three upper floors & a seprate hall at ground floor only, was issued FSC vide letter No. F6/DFS/MS/School/SZ/2022/339 dated 29/03/2022) & (Block-II ground and one upper floor only was at issued FSC vide letter No. F6/DFS/MS/School/2021/SZ/536 dated 27/07/2021 except dangerous block – Room No. 06,07,08,107,108,109). The school building/premises was re - inspected by the officer concerned of this department on 19/12/2024 in the presence of Sh. Prabhat Kumar (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 30/12/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 30/12/2024 at New Delhi.

(Anul Garg)
Director

Copy to:

1. The Principal, Govt. Boys Sr. Sec. School, Rajouri Garden, Extn. New delhi-110027. (School ID- 1515018)
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. This NOC is valid for Ground & 3rd floors block and ground & one upper floor block (except dangerous block 03 rooms ground floor and 03 rooms 1st floor) only.

INSPECTION REPORT

1. Name & address of the building	Govt. Boys Sr. Sec. School, Rajouri Garden, Extn. New delhi-110027. (School ID- 1515018)
2. Type of Occupancy	Educational (Two Blocks) (Ground Plus three Upper floors with one hall & ground plus on upper floors.)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/2022/339 dated 29/03/2022 for G + 03upper floors & F6/DFS/MS/School/2021/SZ/536 dated 27/04/2021 for G + 01 upper floor
5. Fire Safety directives letter No	Nil
6. Date of inspection	18/12/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Smt. Prabhat Kumar (Principal)
9. Year of Construction	2020 (As per previous insp. report dtd.-24/03/2020) & 2014 (As per previous isnp. report dtd 12/07/2021)
10. Applicant's letter No.	Letter no. GBSSS/RGE/2024/665 dated 28/11/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 Mtr.	Provided	MR
	• Gate width	4.5 Mtr.	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 in each block	02 Provided in each block	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5 mts	Provided	MR
	g. Door Size	1.20 m.& 1.0m For G+1	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

b
8

6	First-Aid Hose Reels.			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.			
		Required	Provided	MR

N/N

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

NOTE:- This NOC is valid for Ground & 3rd floors block and ground & one upper floor block (except dangerous block 03 rooms ground floor and 03 rooms 1st floor) only.

The Fire Protection system provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules FSC issued vide letter number F6/DFS/MS/School/2022/339 dated 29/03/2022 & F6/DFS/MS/School/2021/SZ/536 dated 27/04/2021, it is recommended to renewal Fire safety certificate under Delhi Fire Service Act-2007 & rules-2010.

(Signature)
24/12/2024

(Signature)
20/12/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

(Signature)
23/12

355/ADO/MN
21/12/2024

DCFO...S24...ND...
Date: 23/12/2024

(Signature) OR Cease
Director (DOFS)
24/12/24

Signature please.
(Signature)
21/12/24

(Signature) Sir F.T is put up
for you kind personal &
(Signature)
27/12/2024