




C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001
 No F 6 / DFS / MS / 2024/ School/WZ/ 1247
FIRE SAFETY CERTIFICATE

Dated: 31/12/2024


Certified that the Govt. Co-ed Sr. Sec. School (ID- 1310030) located at Holambi Kalan, Delhi-110082 comprised of Ground plus three upper floors was issued FSC by this department vide letter No F6/DFS/MS/2022/School/WZ/348 dated 31.03.2022. The premises was re-inspected by the officer concerned of this department on 26.12.2024 in the presence of Sh. Ashish Kumar (H.O.S.), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy Group B Educational with effect from31.12.2024 for a period of three years, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on31.12.2024 at New Delhi, by


 (Atul Garg)
 Director
 Ph. 011-23414000


Copy to: -

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054.
2. The Principal, Govt. Co-ed Sr. Sec. School (ID- 1310030) located at Holambi Kalan, Delhi-110082.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed Sr. Sec. School (ID-1310030) located at Holambi Kalan, Delhi- 110082.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground plus Three Upper Floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2022/School/WZ/348 Dated- 31/03/2022
6. Fire Safety directives letter No : NBC Part IV
7. Date of inspection : 26/12/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. Ashish Kumar (H.O.S.)
10. Year of Construction : 2021
11. Applicant's letter No. : E Mail ID dated 03/12/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1.20 m	Provided with double door	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	20 Nos.	46 Nos.	MR
	• Types	ABC/ Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA

Build
Special Fire
Protection

N-23

8.	MOEFA				NA
9.	Public Address System				NA
10.	Automatic Sprinkler System				NA
	• Basement				NA
	• Ground Floor				NA
	• Sprinkler above false ceiling				NA
11.	Internal Hydrants				
	• Size of riser/down-comer				NA
	• Number of hydrants per floor				NA
	• Hose Box				NA
12.	Yard Hydrants				
	• Total number of hydrants				NA
	• Hose Box				NA
13.	Pumping Arrangements				
	• Ground Level				NA
	➤ Discharge of main Pump				NA
	➤ Head of Main pump				NA
	➤ Number of main pumps				NA
	➤ Jockey Pump out put				NA
	➤ Jockey pump head				NA
	➤ Standby Pump out put				NA
	➤ Standby Pump Head				NA
	➤ Auto Starting/Manual Stopping				NA
	➤ Pump House Access				NA
	• Terrace level				MR
	➤ Discharge of pump	450 lpm	2 x 450 lpm		MR
	➤ Head of the pump	40 m	Provided		
	➤ Power Supply	Required	Provided		MR
	➤ Auto Starting of pump	Required	Provided		MR
14.	Captive Water Storage for fire fighting				
	• Underground tank capacity				NA
	➤ Draw-off connection				NA
	➤ Fire service inlet				NA
	➤ Access to tank				NA
	• Overhead Tank capacity	10,000 ltrs	Provided		MR
		Required	Provided		MR
15.	Exit Signage.				
16.	Provision of Lifts.				
	• Pressurization of Lift Shaft				NA
	• Pressurization of Lift lobby				NA
	• Communication In lift Car				NA
	• Fireman's Grounding Switch				NA
	• Lift Signage				NA
17.	Standby power supply				
18.	Refuge Area.				
	➤ Total Area				NA
	➤ Location				NA
19.	Fire Control Room				
	• Detector System Panel				NA
	• Flow Switch Panel				NA
	• PA System Panel				NA
	• Battery backup				NA

PV

N-24

NA

Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note:- Electric meter and electrical panel are not under the staircase.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/2022/School/WZ/348 dated 31/03/2022 under rule 37 of the Delhi Fire Service Rules, 2010.

ADO(BW)
26/12/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Do (BW)

26/12/2024

By cfo (WZ)

26/12

cfo / Wuz
27/12/2024

Secretary
27/12

Sri: At letter ni putap for sign please

ADO(BW)
30/12/24

Secretary
31/12/24
mu

dated... 27/12/2024