



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DE LHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2024/NDZ/1242

Dated: 31/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Saai Memorial Girls School, located at Sai Bhawan, Geeta Colony, Delhi-110031, building comprised of **Ground plus three upper floor only**, owned / occupied by Saai Memorial Girls School, was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/974 Dated 02/12/2021. The School building was re-inspected by the officer concerned of this department on 21/12/2024 in presence of Smt. Meenakshi Keswani (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Delhi Fire Service Act,2007 and Rule 2010 and that the building is fit for occupancy class "**Educational**" (Group-B) with effect from 31/12/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 31/12/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.

o/c ADT

Copy to:-

1. The Principal, Saai Memorial Girls School, Sai Bhawan, Geeta Colony, Delhi-110031.
2. Dy Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

N/20

INSPECTION REPORT

1. Name & address of the building: Saai Memorial Girls School, Sai Bhawan,
Geeta Colony, Delhi-110031
2. Building is comprised of : Ground+three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2021/NDZ/974
Dated 02/12/2021
6. Fire Safety directives Letter No.: Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of inspection : 21/12/2024
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer
from the building side : Smt. Meenakshi Keswani (Principal)
10. Year of Construction : 2004
11. Applicant's letter No. : Email Dated:25/11/2024

S.No.	Minimum Standards on fire prevention and fire safety U/R 33 Requirements	Provided at Site	Remarks
1	Access to building		
	• Road width	06 m	12 m ✓
	• Gate width	N/A	N/A
	• Width of internal road	N/A	N/A
2	Number, Width, Type and Arrangement of Exits		
	a. Number of Staircases		
	• Upper floors	02 nos.	02 nos.
	• Basement	N/A	N/A
	b. Width of Staircases		
	• Upper Floor	1.5m	1.6 m & 1m & 0.94
	• Basement	/add.0.75 m	m(GF to FF Only)
	c. Protection of exits		
	• Fire check door	N/A	N/A
	• Pressurization	N/A	N/A
	d. No. of continuous staircases to terrace		
		1 nos	1 nos.
	e. Width of Corridor	1.5 m	1.5m
	f. Door size	1 m	1 m
3	Compartmentation		
	• Fire check Door	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A
	• Water Curtain	N/A	N/A
	• Fire Dampers	N/A	N/A
4	Smoke Management System		
	• Basement	N/A	N/A
	• Upper Floors	N/A	N/A
5	Fire Extinguishers		
	• Total Numbers	07	10 ✓
	• Types	ABC & Co2	ABC & Co2
	• IS Marking	ISI Marked	ISI Marked

A

6	First-aid-Hose Reels			
	• Total numbers of each floor	2 nos.	2 nos.	M/R
	• Length of hose reel hose	30 m	30m	M/R
	• Nozzle diameter	5mm	5mm	M/R
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	M/R
9	Public address System	N/A	Provided	M/R
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	N/A	100 mm	M/R
	• Number of Hydrants per Floor	N/A	2 nos.	M/R
	• Hose Box	N/A	2 nos.	M/R
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	M/R
	➤ head of the pump	40 m	40 m	M/R
	➤ Power supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	50,000 Lts.	M/R
	➤ Draw-off connection	N/A	Provided	M/R
	➤ Fire service inlet	N/A	Provided	M/R
	➤ Access to tank	N/A	Provided	M/R
	• overhead Tank capacity	10,000 Lts.	10,000 Lts.	M/R
15	Exit Signage	Required	Provided	M/R

N/22

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided /	M/R
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	

Note:- As told by principal, earlier Basement was existing which is filled and completely sealed by brick/concrete work by school management due to flood prone area. One temporary room on the terrace also found sealed.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required in Director of Education Circular No. Delhi Fire Service Act, 2007 and Rule 2010, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2021/NDZ/974 Dated 02/12/2021 is recommended to be renewed.

Ak Jaiswal
23/12/2024
Signature of the Inspecting Officer
Name: Ashok Kumar Jaiswal
Designation: D.O. (East. Div.)

Dy. CFO (NDZ)

RVP
26/12/24

CFO
27/12/2024
Director
27/12/24

DC/Prin

F.T. is added for sign. pl.

Director
27/12/24

Ak Jaiswal
30/12/2024