

C/55

No.F6/DFS/MS/School/SZ/2024/1241

Dated: 30/12/2024

FIRE SAFETY CERTIFICATE

Certified that the **Saraswati Bal Mandir, A Block, Amar Colony, Lajpat Nagar- IV, New Delhi- 110022**, comprised of **Ground + 02 upper floors** was granted Fire Safety Certificate by this department vide letter no.- F6/DFS/MS/School/2021/SZ/1055 dated 22.12.2021. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 20.12.2024 in the presence of Mrs. Anju Sharma (Principal) and found that building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and the building/premises (**Ground + 02 upper floors**) is fit for occupancy of Group B "**Educational Building**" with effect from 30/12/24..... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.. 30/12/24.....at New Delhi by

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. The Principal, Saraswati Bal Mandir, A Block, Amar Colony, Lajpat Nagar- IV, New Delhi- 110022.

Conditions for the validity of Fire Safety Certificate

1. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Saraswati Bal Mandir, A Block, Amar Colony, Lajpat Nagar- IV, New Delhi- 110022.		
2	Building is comprised of	Ground + 02 upper floors		
3	Type of occupancy	Group B- Education Building (School)		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/SZ/1055 dated 22.12.2021		
6	Fire safety direction letter no.	F6/DFS/MS/BP/2002/404 dated 11.03.2002		
7	Date of inspection	20.12.2024		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mrs. Anju Sharma (Principal)		
10	Year of construction	2002-03		
11	Applicant's letter no.	Outdoor diary no. 9772 dated 02.12.2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	Required	6.0 m	MR
B	Gate width	Required	4.5 m	MR
C	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases		02 nos.	MR
	a	Upper floor	01 no.	NA
	b	Basement	NA	NA
B	Width of staircases		1.50 m each	MR
	a	Upper floor	Required	NA
	b	Basement	NA	NA
C	Protection of exits		NA	NA
	a	Fire check door	NA	NA
	b	Pressurization	NA	NA
D	No. of continuous staircases to terrace		02 nos.	MR
E	Width of corridor		2.15 m	MR
F	Door size		1.10 m	MR
		1.50 m	1.0 m for class room	
3	Compartmentation:			
A	Fire check door		NA	NA
B	Sealing of electrical shafts		NA	NA
C	Fire rating of shaft door		NA	NA
D	Water curtain		NA	NA
E	Fire dampers		NA	NA
4	Smoke Management System:			
A	Basement		30 ACPH	NA
B	Upper floor		12 ACPH	NA
5.	Fire Extinguisher:			
A	Total numbers		12 nos.	MR
B	Types		CO ₂ & ABC	MR
C	ISI marking		ISI Marked	MR
6	First-Aid-Hose Reel:			
A	Total numbers of each floor		02 nos.	MR
B	Length of hose reel hose		30 mtrs.	MR
C	Nozzle diameter		05 mm	MR

7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8 MOEFA:				
9 Public Address System:				
10 Automatic Sprinkler System:				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants:				
A	Size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12 Yard Hydrants:				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13 Pumping Arrangements:				
A Ground level				
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
B Terrace Level				
a)	Discharge of pump	900 LPM	900 LPM	MR
b)	Head of the pump	40 mtrs	40 m	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR
14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	15,000 ltrs	Provided	MR
15 Exit Signage:				
		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17 Standby Power Supply:				
		NA	NA	NA
18 Refuge Area:				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA



19	Fire Control Room:			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	PA system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		NA	NA

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/School/2021/SZ/1055 dated 22.12.2021 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

[Handwritten Signature]
22/12/21

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD) *[Handwritten Signature]*

CFO (MS) *[Handwritten Signature]*
27/12/2021

Director *[Handwritten Signature]*