



c/40

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 1235

Dated: 27/12/2024

**FIRE SAFETY CERTIFICATE**

Certified that **The British School including Auditorium** located at Dr. Jose P Rizal Marg, Chanakyapuri, New Delhi-110021, comprised of **02 tier basement, ground & four upper floors**, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/21 dated 06/01/2022. The premise was re-inspected by the officer concerned of this department on 18/12/2024 in the presence of Mr. Yashpal (Estate Manager) and found that the said building/premises have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Group-B, Educational**" (School up to Sr. Secondary level) with effect from 27/12/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/12/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Principal, The British School located at Dr. Jose P Rizal Marg, Chanakyapuri, New Delhi-110021
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used strictly in accordance with the Building Bye-Laws.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N-12

INSPECTION REPORT				
1.	Name & address of the building	The British School, Dr. Jose P Rizal Marg, Chanakyapuri, New Delhi-110021		
2.	Type of Occupancy	Educational Building (Group-B) School up to senior secondary level.		
3.	Building Comprised of	2 Tier B + G + 4 UFs (Including Auditorium)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/School/2022/SZ/21 Dt. 06/01/2022		
6.	Fire Safety directives Letter No.	F6/DFS/MS/BP/2011/2028 Dt. 19/08/2011		
7.	Date of inspection	19/12/2024		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Mr. Yashpal (Estate Manager)		
10.	Year of Construction	2014 (Phase-I) & 2016 (Phase-II)		
11.	Applicant's letter No.	Outdoor diary No. 9833 dated 02/12/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtr	20mtr	MR
	• Gate width	4.5mtr	6mtr	MR
	• Width of internal road	6mtr	6mtr	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	08 Nos	12 Nos	MR
	• Basements	04 Nos	UB=05, LB=03	MR
	b. Width of staircases			
	• Upper floors	8 of 1.5m & 3 of 2m	8x1.50m + 4x2m (GF to FF) 9x1.5m + 4x2m (FF to SF) 8x1.5m + 4x2m (3 <sup>rd</sup> to 4 <sup>th</sup> )	MR
	• Basements	3x1.5m & 1 x2m+1ramp	UB=4x1.5m, 1x2m + 1ramp LB=-2x1.5m, 1x2m + 1ramp	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	08 Nos	Provided	MR
	e. Width of Corridor	-NA-	2mtr	-NA-
	f. Door Size	1m x2 & 2m x 6nos in Audi	1m x 2 & 2m x 6nos in Audi	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	2 hrs.	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke Managements System			
	• Basements	30 ACPH	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	• Total numbers	100 Nos	120 Nos	MR
	• Types	ABC/CO <sub>2</sub>	CO <sub>2</sub> , ABC & W.CO <sub>2</sub>	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	LB & UB=04, GF to 2 <sup>nd</sup> -09 & 3 <sup>rd</sup> to 4 <sup>th</sup> -08	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

8

N-13

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & Heat	Provided	MR
		FCR at GF	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		All floors	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	Provided	MR
		LB & UB=04, GF to SF =09 & 3 <sup>rd</sup> to 4 <sup>th</sup> = 08nos	Provided	MR
		LB & UB=04, GF to SF =09 & 3 <sup>rd</sup> to 4 <sup>th</sup> = 08nos	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	04 Nos	10 Nos	MR
		04 Nos	10 Nos	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> </ul>	2280+2x2850 LPM	Provided	MR
		70m	Provided	MR
		03 Nos	Provided	MR
		2nos of 280 LPM	Provided	MR
		70m	Provided	MR
		2850 LPM	Provided	MR
		70m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	900 LPM	2 x 900 LPM	MR
		40m	40m each	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for firefighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	-NA-	1,00,000 Ltr	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		25,000 Ltr	40,000 Ltr	MR
		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

CA

N-14

19.	Fire Control Room	Required	Provided	MR
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	Provided	MR

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/21 dated 06/01/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Santosh Kumar*  
20/12/24

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD) *[Signature]*  
26/12/24

CFO (MS) *[Signature]*  
26/12/2024

Director *[Signature]*  
27/12/24

*ADU/S*

FT Pls Vag vgt

Sir,

F.T. letter is put up for your signature

~~*[Signature]*~~  
*[Signature]*

*Santosh Kumar*  
23/12/24