

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2021/SZ/55

Dated: 21/01/2021

FIRE SAFETY CERTIFICATE

Certified that the **Dev Public School** running at ground plus two upper floors, building is comprised of ground floor plus three upper floors at 58/2, Surya Kunj, Saraswati Kunj, Jharoda Road, Najafgarh, New Delhi-110072, owned/occupied by Dev Public School was issued Fire Safety Certificate by this department vide letter no. **F.6/DFS/MS/School/2017/SZ/1773 dated 08/12/2017**. The School building was re-inspected by the officer concerned of this department on 04/01/2021 in the presence of **Sh. Ran Singh (Manager)** and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises {Ground plus two upper floors (Old Portion)} is fit for occupancy Group "Educational" for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 21/01/2021 at New Delhi.


(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. The Manager,
Dev Public School, 58/2,
Surya Kunj, Saraswati Kunj, Jharoda Road,
Najafgarh, New Delhi-110072.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Dev Public School, 58/2, Surya Kunj, Saraswati Kunj, Jharoda Road, Najafgarh, New Delhi-110072.
2. Building comprised of : ground plus three upper floors but school is running at ground plus two upper floors (old portion) & third floor used for residential purpose.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2017/SZ/1773 dated 08/12/2017
6. Fire Safety directives letter No : N/A
7. Date of inspection : 04/01/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers from the building side : Sh. Ran Singh (Manager)
10. Year of Construction : 2006
11. Applicant's letter No. : TDPS/0349/2020 dated 07/11/2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	07 mtrs 4.5 & 2.2 mtrs N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s N/A	02 No.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m & .m N/A	1.32 & .95 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		1 no.	1 no.	MR
		1.50 m	2.40 m	MR
	e. Width of Corridor	1 m	.90 m	MR, being old case
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	10 no's ABC/CO ₂ type	Provided Provided	MR MR MR

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 no. 30 mtrs 05 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	100 mm One One	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 40 mtrs N/A N/A	N/A Provided Provided N/A N/A	N/A MR MR N/A N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 10,000 ltrs	N/A N/A N/A N/A Provided	N/A N/A N/A N/A MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A

	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2017/SZ/1773 dated 08/12/2017 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per undertaking (placed at C-25) given by the Manager school has ground plus three upper floors but classes and school activities are done only ground, first, second floors & third floor used for residential and students are not more than 40 in each classroom. New block civil work in progress.

R. K. Yadav

Signature of Inspecting Officer 17/1/2021

Name:- R.K. Yadav

Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

R. K. Yadav
17/01/2021
Dy CPO (S2)

F.T. plans

ADD - JKP

FT letter is put up for sign pl.

R. K. Yadav
17/1/2021