

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2021/ 97

DATED: 24/02/2021

To,

The Principal,
Rajkiya Pratibha Vikas Vidhalaya,
Sector – 19 Dwarka,
New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o the Rajkiya Pratibha Vikas Vidhalaya, Located at Sector – 19 Dwarka, New Delhi.

Sir,

This is in reference to your letter no. RPVV/S-19/DWK/2021/23 Dated 29-01-2021 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 09/02/2021.

During the course of inspection followings shortcoming have been observed:-

1. Terrace pump found non functional.
2. Hose reel Hos found nonfunctional.
3. The LPG cylinders are found being used in chemistry lab without any fire safety precaution. The LPG bank must be constructed as per Director of Education circular even no. 3298 -3398 Dated 01/03/2011.

In view of the above renewal of fire safety certificate cannot be considered. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

120/2
18/2