

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021 | 101

Dated: 24/02/2021

To,

The Principal,
Rao Brij Mohan Public School,
Plot No.-7, Brij vihar,
Paprawat, New Delhi-110043.

Subject: Renewal of Fire Safety Certificate iro Rao Brij Mohan Public School, Plot No.-7,
Brij vihar, Paprawat, New Delhi-110043.

Sir,

Please refer to your email dated 04/02/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 16/02/2021 in presence of sh. V K Pandey (Employee) for fire safety point of view.

During course of inspection the following shortcomings were observed:

1. Hose Reel Hose found non functional.
2. The pumps found non functional.
3. Fire water Tank found removed.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Sunil Chaudhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054

100/c
24/2/21